



QUICK RESPONSE FAX OF LABORATORY RESULTS

6/15/2021

Today's Date

PROJECT ID:

TO:

Dale dsharpsteen@moraviaschool.org

Moravia School Dist.

3154972260

COPY TO:

FROM:

LIFE SCIENCE LABORATORIES, INC.

LSL PROJECT ID:

2107149

NUMBER OF PAGES TRANSMITTED:
(INCLUDING COVER PAGE)

117

COMMENTS: _____

Thank you for the opportunity to be of service to you. We appreciate your business. If you need further assistance, please don't hesitate to contact us.

Need help with ...

Questions About Your Results

Price Quotations

Requests for Sample Kits or Scheduling Pickup of Samples

Status of Samples Currently Being Analyzed

Please Ask For ...

The Quality Department

The Client Services Department

The Field Services Department

The Technical Services Department

This facsimile contains CONFIDENTIAL INFORMATION which may also be legally privileged and is intended only for the use of the addressee(s) named above. If you are not the intended recipient of this facsimile, or the employee or agent responsible for delivering it to the intended recipient, you are hereby notified that any dissemination or copying of this facsimile is prohibited. If you have received this facsimile in error, please notify us by telephone and return the original to us via the U. S. Postal Service. Thank You.

If you did not receive all of the pages please contact us immediately at (315) 445-1900.



Life Science Laboratories, Inc.

Date Printed: 6/14/21

Laboratory Analysis Report Prepared For Moravia School Dist.

LSL Project ID: 2107149

Dale
Moravia School Dist.
685 Main St.
Moravia, NY 13118

Phone: (315) 224-9662
FAX: (315) 497-2260

A copy of this report was sent to:

Sample ID: MFE 01
Location:
Sampled: 05/13/21 6:30
Sampled By: ML

LSL Sample ID: 2107149-001
Receive Date/Time: 05/14/21 11:27
Project Rec'd by: tjn1

Matrix: PWS

Analytical Method	Prep Method	Prep Date	Analysis Date & Time	Analyst Initials
Analyte	Result Units			

(1) Lead Study

Number of Samples

107

MT

Please refer to the chain of custody form on the last page of this report for the detailed descriptions of where these samples were taken.

Life Science Laboratories, Inc. warrants, to the best of its knowledge and belief, the accuracy of the analytical test results contained in this report, but makes no other warranty, expressed or implied, especially no warranties of merchantability or fitness for a particular purpose. By the Client's acceptance and/or use of this report, the Client agrees that LSL is hereby released from any and all liabilities, claims, damages or causes of action affecting or which may affect the Client as regards to the results contained in this report. The Client further agrees that the only remedy available to the Client in the event of proven non-conformity with the above warranty shall be for LSL to re-perform the analytical test(s) at no charge to the Client. The data contained in this report are for the exclusive use of the Client to whom it is addressed, and the release of these data to any other party, or the use of the name, trademark or service mark of Life Science Laboratories, Inc. especially for the use of advertising to the general public, is strictly prohibited without express prior written consent of Life Science Laboratories, Inc. This report may only be reproduced in its entirety. No partial duplication is allowed. The Chain of Custody and the Sample Receipt documents submitted with these samples are considered by LSL to be an appendix of this report and may contain data qualifiers and specific information that pertains to the samples included in this report. The analytical result(s) in this report are only representative of the sample(s) submitted for analysis. LSL makes no claim of a sample's representativeness, or integrity, if sampling was not performed by LSL personnel.

LSL Central Lab
5854 Butternut Drive
East Syracuse, NY 13057
Tel. (315) 445-1900
Fax (315) 445-1104
NYS DOH ELAP #10248

LSL North Lab
131 St. Lawrence Avenue
Waddington, NY 13694
Tel. (315) 388-4476
Fax (315) 388-4061
NYS DOH ELAP #10900

LSL Finger Lakes Lab
16 N. Main St., PO Box 424
Wayland, NY 14572
Tel. (585) 213-4090
Fax (585) 213-4192
NYS DOH ELAP #11667

LSL Southern Tier Office
Cuba, NY
Tel. (585) 209-4032

LSL MidLakes Office
Canandaigua, NY
Tel. (585) 728-3320

Reviewed by:

Kristin E. Carpenter
Kristin E. Carpenter, Quality Staff

Date:

06/14/21

Analysis performed at: (1) LSL Central Lab, (2) LSL North Lab, (3) LSL Finger Lakes Lab



Life Science Laboratories, Inc.
 5854 Butternut Drive
 East Syracuse , NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Moravia School Dist.
Location:
Matrix: PWS

Client Sample ID: *MFE 01*
Lab ID: 2107149-001A
Collection Date: 05/13/21 6:30
Date Received: 05/14/21 11:27

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	< 0.0010	mg/L	06/01/21 16:57

- Qualifiers:**
- * Value may exceed the Acceptable Level
 - E Value exceeds the instrument calibration range
 - J Analyte detected below the PQL
 - P Prim./Conf. column %D or RPD exceeds limit
 - B Analyte detected in the associated Method Blank
 - H Holding times for preparation or analysis exceeded
 - ND Not Detected at the Practical Quantitation Limit (PQL)
 - S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.

5854 Butternut Drive
East Syracuse, NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Moravia School Dist.
Location:
Matrix: PWS

Client Sample ID: MFE 02
Lab ID: 2107149-002A
Collection Date: 05/13/21 6:30
Date Received: 05/14/21 11:27

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	0.0017	mg/L	06/01/21 16:59

- Qualifiers:**
- * Value may exceed the Acceptable Level
 - E Value exceeds the instrument calibration range
 - J Analyte detected below the PQL
 - P Prim./Conf. column %D or RPD exceeds limit
 - B Analyte detected in the associated Method Blank
 - H Holding times for preparation or analysis exceeded
 - ND Not Detected at the Practical Quantitation Limit (PQL)
 - S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.
 5854 Butternut Drive
 East Syracuse, NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Moravia School Dist.
Location:
Matrix: PWS

Client Sample ID: MFE 03
Lab ID: 2107149-003A
Collection Date: 05/13/21 6:30
Date Received: 05/14/21 11:27

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8, Rev. 5.4	(EPA 200.2)
Lead	< 0.0010	mg/L	06/01/21 17:01

- | | | |
|--------------------|--|---|
| Qualifiers: | * Value may exceed the Acceptable Level | B Analyte detected in the associated Method Blank |
| | E Value exceeds the instrument calibration range | H Holding times for preparation or analysis exceeded |
| | J Analyte detected below the PQL | ND Not Detected at the Practical Quantitation Limit (PQL) |
| | P Prim./Conf. column %D or RPD exceeds limit | S Spike Recovery outside accepted recovery limits |



Life Science Laboratories, Inc.
 5854 Butternut Drive
 East Syracuse , NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Moravia School Dist.
Location:
Matrix: PWS

Client Sample ID: MFE 04
Lab ID: 2107149-004A
Collection Date: 05/13/21 6:30
Date Received: 05/14/21 11:27

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	0.0015	mg/L	06/01/21 17:12

- Qualifiers:**
- * Value may exceed the Acceptable Level
 - E Value exceeds the instrument calibration range
 - J Analyte detected below the PQL
 - P Prim./Conf. column %D or RPD exceeds limit
 - B Analyte detected in the associated Method Blank
 - H Holding times for preparation or analysis exceeded
 - ND Not Detected at the Practical Quantitation Limit (PQL)
 - S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.
 5854 Butternut Drive
 East Syracuse, NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Moravia School Dist.
Location:
Matrix: PWS

Client Sample ID: MFE 05
Lab ID: 2107149-005A
Collection Date: 05/13/21 6:30
Date Received: 05/14/21 11:27

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	0.0016	mg/L	06/01/21 17:14

- Qualifiers:**
- * Value may exceed the Acceptable Level
 - E Value exceeds the instrument calibration range
 - J Analyte detected below the PQL
 - P Prim./Conf. column %D or RPD exceeds limit
 - B Analyte detected in the associated Method Blank
 - H Holding times for preparation or analysis exceeded
 - ND Not Detected at the Practical Quantitation Limit (PQL)
 - S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.

5854 Butternut Drive
East Syracuse, NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Moravia School Dist.
Location:
Matrix: PWS

Client Sample ID: MFE 06
Lab ID: 2107149-006A
Collection Date: 05/13/21 6:35
Date Received: 05/14/21 11:27

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	0.0027	mg/L	06/01/21 17:16

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.
 5854 Butternut Drive
 East Syracuse, NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Moravia School Dist.
Location:
Matrix: PWS

Client Sample ID: MFE 07

Lab ID: 2107149-007A
Collection Date: 05/13/21 6:35
Date Received: 05/14/21 11:27

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8, Rev. 5.4	(EPA 200.2)
Lead	< 0.0010	mg/L	06/01/21 17:18

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.
 5854 Butternut Drive
 East Syracuse, NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Moravia School Dist.
Location:
Matrix: PWS

Client Sample ID: MFE 08
Lab ID: 2107149-008A
Collection Date: 05/13/21 6:41
Date Received: 05/14/21 11:27

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	< 0.0010	mg/L	06/01/21 17:20

- | | | |
|--------------------|--|---|
| Qualifiers: | * Value may exceed the Acceptable Level | B Analyte detected in the associated Method Blank |
| | E Value exceeds the instrument calibration range | H Holding times for preparation or analysis exceeded |
| | J Analyte detected below the PQL | ND Not Detected at the Practical Quantitation Limit (PQL) |
| | P Prim./Conf. column %D or RPD exceeds limit | S Spike Recovery outside accepted recovery limits |



Life Science Laboratories, Inc.
 5854 Butternut Drive
 East Syracuse, NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Moravia School Dist.
Location:
Matrix: PWS

Client Sample ID: *MFE 09*
Lab ID: 2107149-009A
Collection Date: 05/13/21 6:41
Date Received: 05/14/21 11:27

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8, Rev.5.4	(EPA 200.2)
Lead	0.0056	mg/L	06/01/21 17:26

- Qualifiers:**
- * Value may exceed the Acceptable Level
 - E Value exceeds the instrument calibration range
 - J Analyte detected below the PQL
 - P Prim./Conf. column %D or RPD exceeds limit
 - B Analyte detected in the associated Method Blank
 - H Holding times for preparation or analysis exceeded
 - ND Not Detected at the Practical Quantitation Limit (PQL)
 - S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.
 5854 Butternut Drive
 East Syracuse, NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Moravia School Dist.
Location:
Matrix: PWS

Client Sample ID: MFE10
Lab ID: 2107149-010A
Collection Date: 05/13/21 6:41
Date Received: 05/14/21 11:27

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	0.0026	mg/L	06/01/21 17:28

- Qualifiers:**
- * Value may exceed the Acceptable Level
 - E Value exceeds the instrument calibration range
 - J Analyte detected below the PQL
 - P Prim./Conf. column %D or RPD exceeds limit
 - B Analyte detected in the associated Method Blank
 - H Holding times for preparation or analysis exceeded
 - ND Not Detected at the Practical Quantitation Limit (PQL)
 - S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.
 5854 Butternut Drive
 East Syracuse, NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Moravia School Dist.
Location:
Matrix: PWS

Client Sample ID: MFE11

Lab ID: 2107149-011A
Collection Date: 05/13/21 6:44
Date Received: 05/14/21 11:27

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	0.0016	mg/L	06/01/21 17:30

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.
 5854 Butternut Drive
 East Syracuse, NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Moravia School Dist.
Location:
Matrix: PWS

Client Sample ID: MFE12
Lab ID: 2107149-012A
Collection Date: 05/13/21 6:44
Date Received: 05/14/21 11:27

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	0.0032	mg/L	06/01/21 17:32

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.
 5854 Butternut Drive
 East Syracuse, NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Moravia School Dist.
Location:
Matrix: PWS

Client Sample ID: MFE13
Lab ID: 2107149-013A
Collection Date: 05/13/21 6:44
Date Received: 05/14/21 11:27

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	0.0017	mg/L	06/01/21 17:38

- | | | |
|--------------------|--|---|
| Qualifiers: | * Value may exceed the Acceptable Level | B Analyte detected in the associated Method Blank |
| | E Value exceeds the instrument calibration range | H Holding times for preparation or analysis exceeded |
| | J Analyte detected below the PQL | ND Not Detected at the Practical Quantitation Limit (PQL) |
| | P Prim./Conf. column %D or RPD exceeds limit | S Spike Recovery outside accepted recovery limits |



Life Science Laboratories, Inc.
 5854 Butternut Drive
 East Syracuse, NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Moravia School Dist.
Location:
Matrix: PWS

Client Sample ID: MFE39
Lab ID: 2107149-014A
Collection Date: 05/13/21 6:45
Date Received: 05/14/21 11:27

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	< 0.0010	mg/L	06/01/21 17:40

- Qualifiers:**
- * Value may exceed the Acceptable Level
 - E Value exceeds the instrument calibration range
 - J Analyte detected below the PQL
 - P Prim./Conf. column %D or RPD exceeds limit
 - B Analyte detected in the associated Method Blank
 - H Holding times for preparation or analysis exceeded
 - ND Not Detected at the Practical Quantitation Limit (PQL)
 - S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.
 5854 Butternut Drive
 East Syracuse, NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Moravia School Dist.
Location:
Matrix: PWS

Client Sample ID: MFE15
Lab ID: 2107149-015A
Collection Date: 05/13/21 10:00
Date Received: 05/14/21 11:27

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	0.014	mg/L	06/01/21 17:42

- Qualifiers:**
- * Value may exceed the Acceptable Level
 - E Value exceeds the instrument calibration range
 - J Analyte detected below the PQL
 - P Prim./Conf. column %D or RPD exceeds limit
 - B Analyte detected in the associated Method Blank
 - H Holding times for preparation or analysis exceeded
 - ND Not Detected at the Practical Quantitation Limit (PQL)
 - S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.
 5854 Butternut Drive
 East Syracuse, NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Moravia School Dist.
Location:
Matrix: PWS

Client Sample ID: MFE16
Lab ID: 2107149-016A
Collection Date: 05/13/21 10:00
Date Received: 05/14/21 11:27

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	0.0075	mg/L	06/01/21 17:48

- Qualifiers:**
- * Value may exceed the Acceptable Level
 - E Value exceeds the instrument calibration range
 - J Analyte detected below the PQL
 - P Prim./Conf. column %D or RPD exceeds limit
 - B Analyte detected in the associated Method Blank
 - H Holding times for preparation or analysis exceeded
 - ND Not Detected at the Practical Quantitation Limit (PQL)
 - S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.
 5854 Butternut Drive
 East Syracuse , NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Moravia School Dist.
Location:
Matrix: PWS

Client Sample ID: MFE17
Lab ID: 2107149-017A
Collection Date: 05/13/21 10:00
Date Received: 05/14/21 11:27

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	0.012	mg/L	06/01/21 17:50

- Qualifiers:**
- * Value may exceed the Acceptable Level
 - E Value exceeds the instrument calibration range
 - J Analyte detected below the PQL
 - P Prim./Conf. column %D or RPD exceeds limit
 - B Analyte detected in the associated Method Blank
 - H Holding times for preparation or analysis exceeded
 - ND Not Detected at the Practical Quantitation Limit (PQL)
 - S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.
 5854 Butternut Drive
 East Syracuse, NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Moravia School Dist.
Location:
Matrix: PWS

Client Sample ID: MFE18
Lab ID: 2107149-018A
Collection Date: 05/13/21 10:00
Date Received: 05/14/21 11:27

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	0.014	mg/L	06/01/21 17:51

- Qualifiers:**
- * Value may exceed the Acceptable Level
 - E Value exceeds the instrument calibration range
 - J Analyte detected below the PQL
 - P Prim./Conf. column %D or RPD exceeds limit
 - B Analyte detected in the associated Method Blank
 - H Holding times for preparation or analysis exceeded
 - ND Not Detected at the Practical Quantitation Limit (PQL)
 - S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.
 5854 Butternut Drive
 East Syracuse, NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Moravia School Dist.
Location:
Matrix: PWS

Client Sample ID: MFE19

Lab ID: 2107149-019A
Collection Date: 05/13/21 10:00
Date Received: 05/14/21 11:27

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	0.027 *	mg/L	06/01/21 17:53

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.
 5854 Butternut Drive
 East Syracuse, NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Moravia School Dist.
Location:
Matrix: PWS

Client Sample ID: MFE20
Lab ID: 2107149-020A
Collection Date: 05/13/21 10:00
Date Received: 05/14/21 11:27

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	0.021 *	mg/L	06/01/21 17:55

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.
 5854 Butternut Drive
 East Syracuse, NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Moravia School Dist.
Location:
Matrix: PWS

Client Sample ID: MFE21
Lab ID: 2107149-021A
Collection Date: 05/13/21 10:03
Date Received: 05/14/21 11:27

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	0.064 *	mg/L	06/01/21 17:57

- | | | |
|--------------------|--|---|
| Qualifiers: | * Value may exceed the Acceptable Level | B Analyte detected in the associated Method Blank |
| | E Value exceeds the instrument calibration range | H Holding times for preparation or analysis exceeded |
| | J Analyte detected below the PQL | ND Not Detected at the Practical Quantitation Limit (PQL) |
| | P Prim./Conf. column %D or RPD exceeds limit | S Spike Recovery outside accepted recovery limits |



Life Science Laboratories, Inc.
 5854 Butternut Drive
 East Syracuse , NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Moravia School Dist.
Location:
Matrix: PWS

Client Sample ID: MFE22

Lab ID: 2107149-022A
Collection Date: 05/13/21 10:03
Date Received: 05/14/21 11:27

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	0.044 *	mg/L	06/01/21 17:59

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.
 5854 Butternut Drive
 East Syracuse , NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Moravia School Dist.
Location:
Matrix: PWS

Client Sample ID: MFE23
Lab ID: 2107149-023A
Collection Date: 05/13/21 10:03
Date Received: 05/14/21 11:27

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	0.0097	mg/L	06/01/21 18:01

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.
 5854 Butternut Drive
 East Syracuse, NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Moravia School Dist.
Location:
Matrix: PWS

Client Sample ID: *MFE 24*
Lab ID: 2107149-024A
Collection Date: 05/13/21 10:03
Date Received: 05/14/21 11:27

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	0.0062	mg/L	06/01/21 18:03

- Qualifiers:**
- * Value may exceed the Acceptable Level
 - E Value exceeds the instrument calibration range
 - J Analyte detected below the PQL
 - P Prim./Conf. column %D or RPD exceeds limit
 - B Analyte detected in the associated Method Blank
 - H Holding times for preparation or analysis exceeded
 - ND Not Detected at the Practical Quantitation Limit (PQL)
 - S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.
 5854 Butternut Drive
 East Syracuse, NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Moravia School Dist.
Location:
Matrix: PWS

Client Sample ID: MFE26
Lab ID: 2107149-026A
Collection Date: 05/13/21 10:05
Date Received: 05/14/21 11:27

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	< 0.0010	mg/L	06/01/21 18:05

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.
 5854 Butternut Drive
 East Syracuse, NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Moravia School Dist.
Location:
Matrix: PWS

Client Sample ID: MFE27
Lab ID: 2107149-027A
Collection Date: 05/13/21 10:05
Date Received: 05/14/21 11:27

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	0.0012	mg/L	06/01/21 18:11

- Qualifiers:**
- * Value may exceed the Acceptable Level
 - E Value exceeds the instrument calibration range
 - J Analyte detected below the PQL
 - P Prim./Conf. column %D or RPD exceeds limit
 - B Analyte detected in the associated Method Blank
 - H Holding times for preparation or analysis exceeded
 - ND Not Detected at the Practical Quantitation Limit (PQL)
 - S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.
 5854 Butternut Drive
 East Syracuse, NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Moravia School Dist.
Location:
Matrix: PWS

Client Sample ID: MFE28
Lab ID: 2107149-028A
Collection Date: 05/13/21 10:05
Date Received: 05/14/21 11:27

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	0.0023	mg/L	06/01/21 18:13

- Qualifiers:**
- * Value may exceed the Acceptable Level
 - E Value exceeds the instrument calibration range
 - J Analyte detected below the PQL
 - P Prim./Conf. column %D or RPD exceeds limit
 - B Analyte detected in the associated Method Blank
 - H Holding times for preparation or analysis exceeded
 - ND Not Detected at the Practical Quantitation Limit (PQL)
 - S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.
 5854 Butternut Drive
 East Syracuse , NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Moravia School Dist.
Location:
Matrix: PWS

Client Sample ID: MFE29
Lab ID: 2107149-029A
Collection Date: 05/13/21 10:40
Date Received: 05/14/21 11:27

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	0.0013	mg/L	06/01/21 18:15

- Qualifiers:**
- * Value may exceed the Acceptable Level
 - E Value exceeds the instrument calibration range
 - J Analyte detected below the PQL
 - P Prim./Conf. column %D or RPD exceeds limit
 - B Analyte detected in the associated Method Blank
 - H Holding times for preparation or analysis exceeded
 - ND Not Detected at the Practical Quantitation Limit (PQL)
 - S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.
 5854 Butternut Drive
 East Syracuse, NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Moravia School Dist.
Location:
Matrix: PWS

Client Sample ID: MFE30
Lab ID: 2107149-030A
Collection Date: 05/13/21 10:40
Date Received: 05/14/21 11:27

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	0.0010	mg/L	06/01/21 18:17

- Qualifiers:**
- * Value may exceed the Acceptable Level
 - E Value exceeds the instrument calibration range
 - J Analyte detected below the PQL
 - P Prim./Conf. column %D or RPD exceeds limit
 - B Analyte detected in the associated Method Blank
 - H Holding times for preparation or analysis exceeded
 - ND Not Detected at the Practical Quantitation Limit (PQL)
 - S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.
 5854 Butternut Drive
 East Syracuse , NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Moravia School Dist.
Location:
Matrix: PWS

Client Sample ID: MFE31
Lab ID: 2107149-031A
Collection Date: 05/13/21 10:40
Date Received: 05/14/21 11:27

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	< 0.0010	mg/L	06/01/21 18:19

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.
 5854 Butternut Drive
 East Syracuse, NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Moravia School Dist.
Location:
Matrix: PWS

Client Sample ID: MFE32
Lab ID: 2107149-032A
Collection Date: 05/13/21 10:40
Date Received: 05/14/21 11:27

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8, Rev. 5.4	(EPA 200.2)
Lead	0.0064	mg/L	06/01/21 18:21

- Qualifiers:**
- * Value may exceed the Acceptable Level
 - E Value exceeds the instrument calibration range
 - J Analyte detected below the PQL
 - P Prim./Conf. column %D or RPD exceeds limit
 - B Analyte detected in the associated Method Blank
 - H Holding times for preparation or analysis exceeded
 - ND Not Detected at the Practical Quantitation Limit (PQL)
 - S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.
 5854 Butternut Drive
 East Syracuse , NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Moravia School Dist.
Location:
Matrix: PWS

Client Sample ID: MFE33
Lab ID: 2107149-033A
Collection Date: 05/13/21 10:42
Date Received: 05/14/21 11:27

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	0.0039	mg/L	06/01/21 18:23

- Qualifiers:**
- * Value may exceed the Acceptable Level
 - E Value exceeds the instrument calibration range
 - J Analyte detected below the PQL
 - P Prim./Conf. column %D or RPD exceeds limit
 - B Analyte detected in the associated Method Blank
 - H Holding times for preparation or analysis exceeded
 - ND Not Detected at the Practical Quantitation Limit (PQL)
 - S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.
 5854 Butternut Drive
 East Syracuse, NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Moravia School Dist.
Location:
Matrix: PWS

Client Sample ID: MFE34

Lab ID: 2107149-034A
Collection Date: 05/13/21 10:42
Date Received: 05/14/21 11:27

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	0.0085	mg/L	06/01/21 18:29

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.
 5854 Butternut Drive
 East Syracuse , NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Moravia School Dist.
Location:
Matrix: PWS

Client Sample ID: MFE35
Lab ID: 2107149-035A
Collection Date: 05/13/21 10:42
Date Received: 05/14/21 11:27

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	0.0017	mg/L	06/01/21 18:35

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit
- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.
 5854 Butternut Drive
 East Syracuse, NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Moravia School Dist.
Location:
Matrix: PWS

Client Sample ID: MFE36
Lab ID: 2107149-036A
Collection Date: 05/13/21 10:42
Date Received: 05/14/21 11:27

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	0.0037	mg/L	06/01/21 18:37

- | | | |
|--------------------|--|---|
| Qualifiers: | * Value may exceed the Acceptable Level | B Analyte detected in the associated Method Blank |
| | E Value exceeds the instrument calibration range | H Holding times for preparation or analysis exceeded |
| | J Analyte detected below the PQL | ND Not Detected at the Practical Quantitation Limit (PQL) |
| | P Prim./Conf. column %D or RPD exceeds limit | S Spike Recovery outside accepted recovery limits |



Life Science Laboratories, Inc.
 5854 Butternut Drive
 East Syracuse , NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Moravia School Dist.
Location:
Matrix: PWS

Client Sample ID: MFE37
Lab ID: 2107149-037A
Collection Date: 05/13/21 10:44
Date Received: 05/14/21 11:27

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	0.0022	mg/L	06/01/21 18:39

- Qualifiers:**
- * Value may exceed the Acceptable Level
 - E Value exceeds the instrument calibration range
 - J Analyte detected below the PQL
 - P Prim./Conf. column %D or RPD exceeds limit
 - B Analyte detected in the associated Method Blank
 - H Holding times for preparation or analysis exceeded
 - ND Not Detected at the Practical Quantitation Limit (PQL)
 - S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.
 5854 Butternut Drive
 East Syracuse, NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Moravia School Dist.
Location:
Matrix: PWS

Client Sample ID: MFE38
Lab ID: 2107149-038A
Collection Date: 05/13/21 10:44
Date Received: 05/14/21 11:27

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	0.0014	mg/L	06/01/21 18:41

- | | | |
|--------------------|--|---|
| Qualifiers: | * Value may exceed the Acceptable Level | B Analyte detected in the associated Method Blank |
| | E Value exceeds the instrument calibration range | H Holding times for preparation or analysis exceeded |
| | J Analyte detected below the PQL | ND Not Detected at the Practical Quantitation Limit (PQL) |
| | P Prim./Conf. column %D or RPD exceeds limit | S Spike Recovery outside accepted recovery limits |



Life Science Laboratories, Inc.
 5854 Butternut Drive
 East Syracuse, NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Moravia School Dist.
Location:
Matrix: PWS

Client Sample ID: MFE62
Lab ID: 2107149-039A
Collection Date: 05/13/21 10:50
Date Received: 05/14/21 11:27

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	0.013	mg/L	06/01/21 18:43

- Qualifiers:**
- * Value may exceed the Acceptable Level
 - E Value exceeds the instrument calibration range
 - J Analyte detected below the PQL
 - P Prim./Conf. column %D or RPD exceeds limit
 - B Analyte detected in the associated Method Blank
 - H Holding times for preparation or analysis exceeded
 - ND Not Detected at the Practical Quantitation Limit (PQL)
 - S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.
 5854 Butternut Drive
 East Syracuse, NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Moravia School Dist.
Location:
Matrix: PWS

Client Sample ID: MFE63
Lab ID: 2107149-040A
Collection Date: 05/13/21 10:50
Date Received: 05/14/21 11:27

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	0.017 *	mg/L	06/01/21 18:45

- Qualifiers:**
- * Value may exceed the Acceptable Level
 - E Value exceeds the instrument calibration range
 - J Analyte detected below the PQL
 - P Prim./Conf. column %D or RPD exceeds limit
 - B Analyte detected in the associated Method Blank
 - H Holding times for preparation or analysis exceeded
 - ND Not Detected at the Practical Quantitation Limit (PQL)
 - S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.
 5854 Butternut Drive
 East Syracuse , NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Moravia School Dist.
Location:
Matrix: PWS

Client Sample ID: MFE64
Lab ID: 2107149-041A
Collection Date: 05/13/21 10:50
Date Received: 05/14/21 11:27

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	0.017 *	mg/L	06/01/21 18:47

- | | | |
|--------------------|--|---|
| Qualifiers: | * Value may exceed the Acceptable Level | B Analyte detected in the associated Method Blank |
| | E Value exceeds the instrument calibration range | H Holding times for preparation or analysis exceeded |
| | J Analyte detected below the PQL | ND Not Detected at the Practical Quantitation Limit (PQL) |
| | P Prim./Conf. column %D or RPD exceeds limit | S Spike Recovery outside accepted recovery limits |



Life Science Laboratories, Inc.
 5854 Butternut Drive
 East Syracuse, NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Moravia School Dist.
Location:
Matrix: PWS

Client Sample ID: MFE65
Lab ID: 2107149-042A
Collection Date: 05/13/21 10:50
Date Received: 05/14/21 11:27

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	0.019 *	mg/L	06/01/21 18:49

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.
 5854 Butternut Drive
 East Syracuse , NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Moravia School Dist.
Location:
Matrix: PWS

Client Sample ID: MFE45

Lab ID: 2107149-043A
Collection Date: 05/13/21 6:46
Date Received: 05/14/21 11:27

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	0.012	mg/L	06/01/21 18:51

- | | | |
|--------------------|--|---|
| Qualifiers: | * Value may exceed the Acceptable Level | B Analyte detected in the associated Method Blank |
| | E Value exceeds the instrument calibration range | H Holding times for preparation or analysis exceeded |
| | J Analyte detected below the PQL | ND Not Detected at the Practical Quantitation Limit (PQL) |
| | P Prim./Conf. column %D or RPD exceeds limit | S Spike Recovery outside accepted recovery limits |



Life Science Laboratories, Inc.
 5854 Butternut Drive
 East Syracuse, NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Moravia School Dist.
Location:
Matrix: PWS

Client Sample ID: MFE46
Lab ID: 2107149-044A
Collection Date: 05/13/21 6:46
Date Received: 05/14/21 11:27

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8, Rev.5.4	(EPA 200.2)
Lead	0.0069	mg/L	06/01/21 18:53

- Qualifiers:**
- * Value may exceed the Acceptable Level
 - E Value exceeds the instrument calibration range
 - J Analyte detected below the PQL
 - P Prim./Conf. column %D or RPD exceeds limit
 - B Analyte detected in the associated Method Blank
 - H Holding times for preparation or analysis exceeded
 - ND Not Detected at the Practical Quantitation Limit (PQL)
 - S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.
 5854 Butternut Drive
 East Syracuse, NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Moravia School Dist.
Location:
Matrix: PWS

Client Sample ID: MFE47

Lab ID: 2107149-045A
Collection Date: 05/13/21 6:46
Date Received: 05/14/21 11:27

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	0.011	mg/L	06/01/21 18:59

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.
 5854 Butternut Drive
 East Syracuse, NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Moravia School Dist.
Location:
Matrix: PWS

Client Sample ID: MFE49
Lab ID: 2107149-046A
Collection Date: 05/13/21 6:47
Date Received: 05/14/21 11:27

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	0.0030	mg/L	06/01/21 19:01

- Qualifiers:**
- * Value may exceed the Acceptable Level
 - E Value exceeds the instrument calibration range
 - J Analyte detected below the PQL
 - P Prim./Conf. column %D or RPD exceeds limit
 - B Analyte detected in the associated Method Blank
 - H Holding times for preparation or analysis exceeded
 - ND Not Detected at the Practical Quantitation Limit (PQL)
 - S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.
 5854 Butternut Drive
 East Syracuse, NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Moravia School Dist.
Location:
Matrix: PWS

Client Sample ID: MFE50
Lab ID: 2107149-047A
Collection Date: 05/13/21 6:47
Date Received: 05/14/21 11:27

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	0.0030	mg/L	06/01/21 19:03

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.
 5854 Butternut Drive
 East Syracuse , NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Moravia School Dist.
Location:
Matrix: PWS

Client Sample ID: MFE40
Lab ID: 2107149-048A
Collection Date: 05/13/21 6:48
Date Received: 05/14/21 11:27

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	0.012	mg/L	06/01/21 19:05

- Qualifiers:**
- * Value may exceed the Acceptable Level
 - E Value exceeds the instrument calibration range
 - J Analyte detected below the PQL
 - P Prim./Conf. column %D or RPD exceeds limit
 - B Analyte detected in the associated Method Blank
 - H Holding times for preparation or analysis exceeded
 - ND Not Detected at the Practical Quantitation Limit (PQL)
 - S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.
 5854 Butternut Drive
 East Syracuse , NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Moravia School Dist.
Location:
Matrix: PWS

Client Sample ID: MFE41
Lab ID: 2107149-049A
Collection Date: 05/13/21 6:48
Date Received: 05/14/21 11:27

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	0.012	mg/L	06/01/21 19:07

- | | | |
|--------------------|--|---|
| Qualifiers: | * Value may exceed the Acceptable Level | B Analyte detected in the associated Method Blank |
| | E Value exceeds the instrument calibration range | H Holding times for preparation or analysis exceeded |
| | J Analyte detected below the PQL | ND Not Detected at the Practical Quantitation Limit (PQL) |
| | P Prim./Conf. column %D or RPD exceeds limit | S Spike Recovery outside accepted recovery limits |



Life Science Laboratories, Inc.
 5854 Butternut Drive
 East Syracuse , NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Moravia School Dist.
Location:
Matrix: PWS

Client Sample ID: MFE42

Lab ID: 2107149-050A
Collection Date: 05/13/21 6:48
Date Received: 05/14/21 11:27

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	0.010	mg/L	06/01/21 19:09

- Qualifiers:**
- * Value may exceed the Acceptable Level
 - E Value exceeds the instrument calibration range
 - J Analyte detected below the PQL
 - P Prim./Conf. column %D or RPD exceeds limit
 - B Analyte detected in the associated Method Blank
 - H Holding times for preparation or analysis exceeded
 - ND Not Detected at the Practical Quantitation Limit (PQL)
 - S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.
 5854 Butternut Drive
 East Syracuse , NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Moravia School Dist.
Location:
Matrix: PWS

Client Sample ID: MFE43
Lab ID: 2107149-051A
Collection Date: 05/13/21 6:48
Date Received: 05/14/21 11:27

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	0.013	mg/L	06/01/21 19:11

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.
 5854 Butternut Drive
 East Syracuse, NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Moravia School Dist.
Location:
Matrix: PWS

Client Sample ID: MFE53
Lab ID: 2107149-052A
Collection Date: 05/13/21 6:50
Date Received: 05/14/21 11:27

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	0.0072	mg/L	06/01/21 19:13

- Qualifiers:**
- * Value may exceed the Acceptable Level
 - E Value exceeds the instrument calibration range
 - J Analyte detected below the PQL
 - P Prim./Conf. column %D or RPD exceeds limit
 - B Analyte detected in the associated Method Blank
 - H Holding times for preparation or analysis exceeded
 - ND Not Detected at the Practical Quantitation Limit (PQL)
 - S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.
 5854 Butternut Drive
 East Syracuse , NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Moravia School Dist.
Location:
Matrix: PWS

Client Sample ID: MFE54

Lab ID: 2107149-053A
Collection Date: 05/13/21 6:50
Date Received: 05/14/21 11:27

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	0.0026	mg/L	06/01/21 20:11

- Qualifiers:**
- * Value may exceed the Acceptable Level
 - E Value exceeds the instrument calibration range
 - J Analyte detected below the PQL
 - P Prim./Conf. column %D or RPD exceeds limit
 - B Analyte detected in the associated Method Blank
 - H Holding times for preparation or analysis exceeded
 - ND Not Detected at the Practical Quantitation Limit (PQL)
 - S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.
 5854 Butternut Drive
 East Syracuse , NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Moravia School Dist.
Location:
Matrix: PWS

Client Sample ID: MFE55

Lab ID: 2107149-054A
Collection Date: 05/13/21 6:50
Date Received: 05/14/21 11:27

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	0.0036	mg/L	06/01/21 20:17

- Qualifiers:**
- * Value may exceed the Acceptable Level
 - E Value exceeds the instrument calibration range
 - J Analyte detected below the PQL
 - P Prim./Conf. column %D or RPD exceeds limit
 - B Analyte detected in the associated Method Blank
 - H Holding times for preparation or analysis exceeded
 - ND Not Detected at the Practical Quantitation Limit (PQL)
 - S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.
 5854 Butternut Drive
 East Syracuse, NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Moravia School Dist.
Location:
Matrix: PWS

Client Sample ID: MFE56
Lab ID: 2107149-055A
Collection Date: 05/13/21 6:50
Date Received: 05/14/21 11:27

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	0.0032	mg/L	06/01/21 20:19

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.
 5854 Butternut Drive
 East Syracuse, NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Moravia School Dist.
Location:
Matrix: PWS

Client Sample ID: MFE57

Lab ID: 2107149-056A
Collection Date: 05/13/21 6:50
Date Received: 05/14/21 11:27

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	0.0043	mg/L	06/01/21 20:21

- Qualifiers:**
- * Value may exceed the Acceptable Level
 - E Value exceeds the instrument calibration range
 - J Analyte detected below the PQL
 - P Prim./Conf. column %D or RPD exceeds limit
 - B Analyte detected in the associated Method Blank
 - H Holding times for preparation or analysis exceeded
 - ND Not Detected at the Practical Quantitation Limit (PQL)
 - S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.
 5854 Butternut Drive
 East Syracuse, NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Moravia School Dist.
Location:
Matrix: PWS

Client Sample ID: MFE58
Lab ID: 2107149-057A
Collection Date: 05/13/21 6:53
Date Received: 05/14/21 11:27

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	0.0032	mg/L	06/01/21 19:15

- Qualifiers:**
- * Value may exceed the Acceptable Level
 - E Value exceeds the instrument calibration range
 - J Analyte detected below the PQL
 - P Prim./Conf. column %D or RPD exceeds limit
 - B Analyte detected in the associated Method Blank
 - H Holding times for preparation or analysis exceeded
 - ND Not Detected at the Practical Quantitation Limit (PQL)
 - S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.
 5854 Butternut Drive
 East Syracuse, NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Moravia School Dist.
Location:
Matrix: PWS

Client Sample ID: MFE59
Lab ID: 2107149-058A
Collection Date: 05/13/21 6:53
Date Received: 05/14/21 11:27

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	< 0.0010	mg/L	06/01/21 19:25

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.
 5854 Butternut Drive
 East Syracuse, NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Moravia School Dist.
Location:
Matrix: PWS

Client Sample ID: MFE60
Lab ID: 2107149-059A
Collection Date: 05/13/21 6:53
Date Received: 05/14/21 11:27

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	0.0079	mg/L	06/01/21 19:27

- Qualifiers:**
- * Value may exceed the Acceptable Level
 - E Value exceeds the instrument calibration range
 - J Analyte detected below the PQL
 - P Prim./Conf. column %D or RPD exceeds limit
 - B Analyte detected in the associated Method Blank
 - H Holding times for preparation or analysis exceeded
 - ND Not Detected at the Practical Quantitation Limit (PQL)
 - S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.
 5854 Butternut Drive
 East Syracuse , NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Moravia School Dist.
Location:
Matrix: PWS

Client Sample ID: MFE61
Lab ID: 2107149-060A
Collection Date: 05/13/21 6:53
Date Received: 05/14/21 11:27

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	0.0091	mg/L	06/01/21 19:29

- | | | |
|--------------------|--|---|
| Qualifiers: | * Value may exceed the Acceptable Level | B Analyte detected in the associated Method Blank |
| | E Value exceeds the instrument calibration range | H Holding times for preparation or analysis exceeded |
| | J Analyte detected below the PQL | ND Not Detected at the Practical Quantitation Limit (PQL) |
| | P Prim./Conf. column %D or RPD exceeds limit | S Spike Recovery outside accepted recovery limits |



Life Science Laboratories, Inc.
 5854 Butternut Drive
 East Syracuse, NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Moravia School Dist.
Location:
Matrix: PWS

Client Sample ID: MFE76
Lab ID: 2107149-061A
Collection Date: 05/13/21 6:55
Date Received: 05/14/21 11:27

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	0.013	mg/L	06/01/21 19:31

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.
 5854 Butternut Drive
 East Syracuse, NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Moravia School Dist.
Location:
Matrix: PWS

Client Sample ID: MFE77
Lab ID: 2107149-062A
Collection Date: 05/13/21 6:55
Date Received: 05/14/21 11:27

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	0.016 *	mg/L	06/01/21 19:33

- Qualifiers:**
- * Value may exceed the Acceptable Level
 - E Value exceeds the instrument calibration range
 - J Analyte detected below the PQL
 - P Prim./Conf. column %D or RPD exceeds limit
 - B Analyte detected in the associated Method Blank
 - H Holding times for preparation or analysis exceeded
 - ND Not Detected at the Practical Quantitation Limit (PQL)
 - S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.
 5854 Butternut Drive
 East Syracuse, NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Moravia School Dist.
Location:
Matrix: PWS

Client Sample ID: MFE78
Lab ID: 2107149-063A
Collection Date: 05/13/21 6:55
Date Received: 05/14/21 11:27

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	0.031 *	mg/L	06/01/21 19:35

- Qualifiers:**
- * Value may exceed the Acceptable Level
 - E Value exceeds the instrument calibration range
 - J Analyte detected below the PQL
 - P Prim./Conf. column %D or RPD exceeds limit
 - B Analyte detected in the associated Method Blank
 - H Holding times for preparation or analysis exceeded
 - ND Not Detected at the Practical Quantitation Limit (PQL)
 - S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.
 5854 Butternut Drive
 East Syracuse , NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Moravia School Dist.
Location:
Matrix: PWS

Client Sample ID: MFE79
Lab ID: 2107149-064A
Collection Date: 05/13/21 6:55
Date Received: 05/14/21 11:27

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	0.033 *	mg/L	06/01/21 19:37

- Qualifiers:**
- * Value may exceed the Acceptable Level
 - E Value exceeds the instrument calibration range
 - J Analyte detected below the PQL
 - P Prim./Conf. column %D or RPD exceeds limit
 - B Analyte detected in the associated Method Blank
 - H Holding times for preparation or analysis exceeded
 - ND Not Detected at the Practical Quantitation Limit (PQL)
 - S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.
 5854 Butternut Drive
 East Syracuse , NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Moravia School Dist.
Location:
Matrix: PWS

Client Sample ID: MFE82
Lab ID: 2107149-065A
Collection Date: 05/13/21 6:57
Date Received: 05/14/21 11:27

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	0.039 *	mg/L	06/01/21 19:39

- Qualifiers:**
- * Value may exceed the Acceptable Level
 - E Value exceeds the instrument calibration range
 - J Analyte detected below the PQL
 - P Prim./Conf. column %D or RPD exceeds limit
 - B Analyte detected in the associated Method Blank
 - H Holding times for preparation or analysis exceeded
 - ND Not Detected at the Practical Quantitation Limit (PQL)
 - S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.
 5854 Butternut Drive
 East Syracuse , NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Moravia School Dist.
Location:
Matrix: PWS

Client Sample ID: MFE83
Lab ID: 2107149-066A
Collection Date: 05/13/21 6:57
Date Received: 05/14/21 11:27

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	0.026 *	mg/L	06/01/21 19:41

- Qualifiers:**
- * Value may exceed the Acceptable Level
 - E Value exceeds the instrument calibration range
 - J Analyte detected below the PQL
 - P Prim./Conf. column %D or RPD exceeds limit
 - B Analyte detected in the associated Method Blank
 - H Holding times for preparation or analysis exceeded
 - ND Not Detected at the Practical Quantitation Limit (PQL)
 - S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.
 5854 Butternut Drive
 East Syracuse, NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Moravia School Dist.
Location:
Matrix: PWS

Client Sample ID: MFE84
Lab ID: 2107149-067A
Collection Date: 05/13/21 6:57
Date Received: 05/14/21 11:27

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	0.011	mg/L	06/01/21 19:47

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.
 5854 Butternut Drive
 East Syracuse, NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Moravia School Dist.
Location:
Matrix: PWS

Client Sample ID: MFE85
Lab ID: 2107149-068A
Collection Date: 05/13/21 6:57
Date Received: 05/14/21 11:27

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	0.023 *	mg/L	06/01/21 19:49

- Qualifiers:**
- * Value may exceed the Acceptable Level
 - E Value exceeds the instrument calibration range
 - J Analyte detected below the PQL
 - P Prim./Conf. column %D or RPD exceeds limit
 - B Analyte detected in the associated Method Blank
 - H Holding times for preparation or analysis exceeded
 - ND Not Detected at the Practical Quantitation Limit (PQL)
 - S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.
 5854 Butternut Drive
 East Syracuse, NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Moravia School Dist.
Location:
Matrix: PWS

Client Sample ID: MFE66
Lab ID: 2107149-069A
Collection Date: 05/13/21 10:55
Date Received: 05/14/21 11:27

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	0.012	mg/L	06/01/21 19:51

- Qualifiers:**
- * Value may exceed the Acceptable Level
 - E Value exceeds the instrument calibration range
 - J Analyte detected below the PQL
 - P Prim./Conf. column %D or RPD exceeds limit
 - B Analyte detected in the associated Method Blank
 - H Holding times for preparation or analysis exceeded
 - ND Not Detected at the Practical Quantitation Limit (PQL)
 - S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.
 5854 Butternut Drive
 East Syracuse , NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Moravia School Dist.
Location:
Matrix: PWS

Client Sample ID: MFE67
Lab ID: 2107149-070A
Collection Date: 05/13/21 10:55
Date Received: 05/14/21 11:27

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	0.0062	mg/L	06/01/21 19:53

- Qualifiers:**
- * Value may exceed the Acceptable Level
 - E Value exceeds the instrument calibration range
 - J Analyte detected below the PQL
 - P Prim./Conf. column %D or RPD exceeds limit
 - B Analyte detected in the associated Method Blank
 - H Holding times for preparation or analysis exceeded
 - ND Not Detected at the Practical Quantitation Limit (PQL)
 - S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.
 5854 Butternut Drive
 East Syracuse , NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Moravia School Dist.
Location:
Matrix: PWS

Client Sample ID: MFE68
Lab ID: 2107149-071A
Collection Date: 05/13/21 10:55
Date Received: 05/14/21 11:27

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	0.0028	mg/L	06/01/21 19:55

- Qualifiers:**
- * Value may exceed the Acceptable Level
 - E Value exceeds the instrument calibration range
 - J Analyte detected below the PQL
 - P Prim./Conf. column %D or RPD exceeds limit
 - B Analyte detected in the associated Method Blank
 - H Holding times for preparation or analysis exceeded
 - ND Not Detected at the Practical Quantitation Limit (PQL)
 - S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.
 5854 Butternut Drive
 East Syracuse, NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Moravia School Dist.
Location:
Matrix: PWS

Client Sample ID: MFE69
Lab ID: 2107149-072A
Collection Date: 05/13/21 10:55
Date Received: 05/14/21 11:27

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	0.0054	mg/L	06/01/21 19:57

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.
 5854 Butternut Drive
 East Syracuse, NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Moravia School Dist.
Location:
Matrix: PWS

Client Sample ID: MFE70
Lab ID: 2107149-073A
Collection Date: 05/13/21 10:57
Date Received: 05/14/21 11:27

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	0.0044	mg/L	06/01/21 19:59

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.
 5854 Butternut Drive
 East Syracuse, NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Moravia School Dist.
Location:
Matrix: PWS

Client Sample ID: MFE71
Lab ID: 2107149-074A
Collection Date: 05/13/21 10:57
Date Received: 05/14/21 11:27

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	0.0056	mg/L	06/01/21 20:01

- Qualifiers:**
- * Value may exceed the Acceptable Level
 - E Value exceeds the instrument calibration range
 - J Analyte detected below the PQL
 - P Prim./Conf. column %D or RPD exceeds limit
 - B Analyte detected in the associated Method Blank
 - H Holding times for preparation or analysis exceeded
 - ND Not Detected at the Practical Quantitation Limit (PQL)
 - S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.
 5854 Butternut Drive
 East Syracuse, NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Moravia School Dist.
Location:
Matrix: PWS

Client Sample ID: MFE72
Lab ID: 2107149-075A
Collection Date: 05/13/21 10:57
Date Received: 05/14/21 11:27

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	0.0061	mg/L	06/01/21 20:03

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.
 5854 Butternut Drive
 East Syracuse , NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Moravia School Dist.
Location:
Matrix: PWS

Client Sample ID: MFE73
Lab ID: 2107149-076A
Collection Date: 05/13/21 11:00
Date Received: 05/14/21 11:27

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	0.0063	mg/L	06/01/21 20:05

- | | | |
|--------------------|--|---|
| Qualifiers: | * Value may exceed the Acceptable Level | B Analyte detected in the associated Method Blank |
| | E Value exceeds the instrument calibration range | H Holding times for preparation or analysis exceeded |
| | J Analyte detected below the PQL | ND Not Detected at the Practical Quantitation Limit (PQL) |
| | P Prim./Conf. column %D or RPD exceeds limit | S Spike Recovery outside accepted recovery limits |



Life Science Laboratories, Inc.
 5854 Butternut Drive
 East Syracuse, NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Moravia School Dist.
Location:
Matrix: PWS

Client Sample ID: MFE75
Lab ID: 2107149-077A
Collection Date: 05/13/21 11:00
Date Received: 05/14/21 11:27

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	< 0.0010	mg/L	06/01/21 20:23

- Qualifiers:**
- * Value may exceed the Acceptable Level
 - E Value exceeds the instrument calibration range
 - J Analyte detected below the PQL
 - P Prim./Conf. column %D or RPD exceeds limit
 - B Analyte detected in the associated Method Blank
 - H Holding times for preparation or analysis exceeded
 - ND Not Detected at the Practical Quantitation Limit (PQL)
 - S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.
 5854 Butternut Drive
 East Syracuse, NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Moravia School Dist.
Location:
Matrix: PWS

Client Sample ID: MFE110
Lab ID: 2107149-078A
Collection Date: 05/13/21 11:05
Date Received: 05/14/21 11:27

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8, Rev.5.4	(EPA 200.2)
Lead	< 0.0010	mg/L	06/01/21 20:25

- Qualifiers:**
- * Value may exceed the Acceptable Level
 - E Value exceeds the instrument calibration range
 - J Analyte detected below the PQL
 - P Prim./Conf. column %D or RPD exceeds limit
 - B Analyte detected in the associated Method Blank
 - H Holding times for preparation or analysis exceeded
 - ND Not Detected at the Practical Quantitation Limit (PQL)
 - S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.
 5854 Butternut Drive
 East Syracuse, NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Moravia School Dist.
Location:
Matrix: PWS

Client Sample ID: MFE117
Lab ID: 2107149-079A
Collection Date: 05/13/21 11:05
Date Received: 05/14/21 11:27

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	0.0010	mg/L	06/01/21 20:27

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.
 5854 Butternut Drive
 East Syracuse, NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Moravia School Dist.
Location:
Matrix: PWS

Client Sample ID: MFE118
Lab ID: 2107149-080A
Collection Date: 05/13/21 11:06
Date Received: 05/14/21 11:27

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	0.0016	mg/L	06/01/21 20:29

- | | | |
|--------------------|--|---|
| Qualifiers: | * Value may exceed the Acceptable Level | B Analyte detected in the associated Method Blank |
| | E Value exceeds the instrument calibration range | H Holding times for preparation or analysis exceeded |
| | J Analyte detected below the PQL | ND Not Detected at the Practical Quantitation Limit (PQL) |
| | P Prim./Conf. column %D or RPD exceeds limit | S Spike Recovery outside accepted recovery limits |



Life Science Laboratories, Inc.
 5854 Butternut Drive
 East Syracuse, NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Moravia School Dist.
Location:
Matrix: PWS

Client Sample ID: MFE119
Lab ID: 2107149-081A
Collection Date: 05/13/21 11:06
Date Received: 05/14/21 11:27

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	< 0.0010	mg/L	06/01/21 20:35

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.
 5854 Butternut Drive
 East Syracuse, NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Moravia School Dist.
Location:
Matrix: PWS

Client Sample ID: MFE120
Lab ID: 2107149-082A
Collection Date: 05/13/21 11:07
Date Received: 05/14/21 11:27

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	0.0045	mg/L	06/01/21 20:37

- Qualifiers:**
- * Value may exceed the Acceptable Level
 - E Value exceeds the instrument calibration range
 - J Analyte detected below the PQL
 - P Prim./Conf. column %D or RPD exceeds limit
 - B Analyte detected in the associated Method Blank
 - H Holding times for preparation or analysis exceeded
 - ND Not Detected at the Practical Quantitation Limit (PQL)
 - S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.
 5854 Butternut Drive
 East Syracuse, NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Moravia School Dist.
Location:
Matrix: PWS

Client Sample ID: MFE87
Lab ID: 2107149-083A
Collection Date: 05/13/21 7:00
Date Received: 05/14/21 11:27

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	0.012	mg/L	06/01/21 20:39

- Qualifiers:**
- * Value may exceed the Acceptable Level
 - E Value exceeds the instrument calibration range
 - J Analyte detected below the PQL
 - P Prim./Conf. column %D or RPD exceeds limit
 - B Analyte detected in the associated Method Blank
 - H Holding times for preparation or analysis exceeded
 - ND Not Detected at the Practical Quantitation Limit (PQL)
 - S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.
 5854 Butternut Drive
 East Syracuse, NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Moravia School Dist.
Location:
Matrix: PWS

Client Sample ID: MFE88
Lab ID: 2107149-084A
Collection Date: 05/13/21 7:00
Date Received: 05/14/21 11:27

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	0.018 *	mg/L	06/01/21 20:41

- | | | |
|--------------------|--|---|
| Qualifiers: | * Value may exceed the Acceptable Level | B Analyte detected in the associated Method Blank |
| | E Value exceeds the instrument calibration range | H Holding times for preparation or analysis exceeded |
| | J Analyte detected below the PQL | ND Not Detected at the Practical Quantitation Limit (PQL) |
| | P Prim./Conf. column %D or RPD exceeds limit | S Spike Recovery outside accepted recovery limits |



Life Science Laboratories, Inc.
 5854 Butternut Drive
 East Syracuse , NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Moravia School Dist.
Location:
Matrix: PWS

Client Sample ID: MFE89
Lab ID: 2107149-085A
Collection Date: 05/13/21 7:00
Date Received: 05/14/21 11:27

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	0.0055	mg/L	06/01/21 20:43

- | | | |
|--------------------|--|---|
| Qualifiers: | * Value may exceed the Acceptable Level | B Analyte detected in the associated Method Blank |
| | E Value exceeds the instrument calibration range | H Holding times for preparation or analysis exceeded |
| | J Analyte detected below the PQL | ND Not Detected at the Practical Quantitation Limit (PQL) |
| | P Prim./Conf. column %D or RPD exceeds limit | S Spike Recovery outside accepted recovery limits |



Life Science Laboratories, Inc.
 5854 Butternut Drive
 East Syracuse , NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Moravia School Dist.
Location:
Matrix: PWS

Client Sample ID: MFE90
Lab ID: 2107149-086A
Collection Date: 05/13/21 7:03
Date Received: 05/14/21 11:27

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	0.0030	mg/L	06/01/21 20:45

- | | | |
|--------------------|--|---|
| Qualifiers: | * Value may exceed the Acceptable Level | B Analyte detected in the associated Method Blank |
| | E Value exceeds the instrument calibration range | H Holding times for preparation or analysis exceeded |
| | J Analyte detected below the PQL | ND Not Detected at the Practical Quantitation Limit (PQL) |
| | P Prim./Conf. column %D or RPD exceeds limit | S Spike Recovery outside accepted recovery limits |



Life Science Laboratories, Inc.
 5854 Butternut Drive
 East Syracuse , NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Moravia School Dist.
Location:
Matrix: PWS

Client Sample ID: MFE91
Lab ID: 2107149-087A
Collection Date: 05/13/21 7:03
Date Received: 05/14/21 11:27

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	0.0047	mg/L	06/02/21 13:37

- Qualifiers:**
- * Value may exceed the Acceptable Level
 - E Value exceeds the instrument calibration range
 - J Analyte detected below the PQL
 - P Prim./Conf. column %D or RPD exceeds limit
 - B Analyte detected in the associated Method Blank
 - H Holding times for preparation or analysis exceeded
 - ND Not Detected at the Practical Quantitation Limit (PQL)
 - S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.
 5854 Butternut Drive
 East Syracuse, NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Moravia School Dist.
Location:
Matrix: PWS

Client Sample ID: MFE92
Lab ID: 2107149-088A
Collection Date: 05/13/21 7:03
Date Received: 05/14/21 11:27

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	0.011	mg/L	06/01/21 20:49

- | | | |
|--------------------|--|---|
| Qualifiers: | * Value may exceed the Acceptable Level | B Analyte detected in the associated Method Blank |
| | E Value exceeds the instrument calibration range | H Holding times for preparation or analysis exceeded |
| | J Analyte detected below the PQL | ND Not Detected at the Practical Quantitation Limit (PQL) |
| | P Prim./Conf. column %D or RPD exceeds limit | S Spike Recovery outside accepted recovery limits |



Life Science Laboratories, Inc.
 5854 Butternut Drive
 East Syracuse, NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Moravia School Dist.
Location:
Matrix: PWS

Client Sample ID: MFE93
Lab ID: 2107149-089A
Collection Date: 05/13/21 7:05
Date Received: 05/14/21 11:27

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	0.0073	mg/L	06/01/21 20:51

- Qualifiers:**
- * Value may exceed the Acceptable Level
 - E Value exceeds the instrument calibration range
 - J Analyte detected below the PQL
 - P Prim./Conf. column %D or RPD exceeds limit
 - B Analyte detected in the associated Method Blank
 - H Holding times for preparation or analysis exceeded
 - ND Not Detected at the Practical Quantitation Limit (PQL)
 - S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.
 5854 Butternut Drive
 East Syracuse, NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Moravia School Dist.
Location:
Matrix: PWS

Client Sample ID: MFE94

Lab ID: 2107149-090A
Collection Date: 05/13/21 7:08
Date Received: 05/14/21 11:27

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	0.027 *	mg/L	06/01/21 20:53

- Qualifiers:**
- * Value may exceed the Acceptable Level
 - E Value exceeds the instrument calibration range
 - J Analyte detected below the PQL
 - P Prim./Conf. column %D or RPD exceeds limit
 - B Analyte detected in the associated Method Blank
 - H Holding times for preparation or analysis exceeded
 - ND Not Detected at the Practical Quantitation Limit (PQL)
 - S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.
 5854 Butternut Drive
 East Syracuse, NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Moravia School Dist.
Location:
Matrix: PWS

Client Sample ID: MFE95
Lab ID: 2107149-091A
Collection Date: 05/13/21 7:08
Date Received: 05/14/21 11:27

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	0.025 *	mg/L	06/01/21 20:59

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.
 5854 Butternut Drive
 East Syracuse , NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Moravia School Dist.
Location:
Matrix: PWS

Client Sample ID: MFE96
Lab ID: 2107149-092A
Collection Date: 05/13/21 7:08
Date Received: 05/14/21 11:27

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	0.020 *	mg/L	06/01/21 21:01

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.
 5854 Butternut Drive
 East Syracuse, NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Moravia School Dist.
Location:
Matrix: PWS

Client Sample ID: MFE97

Lab ID: 2107149-093A
Collection Date: 05/13/21 7:08
Date Received: 05/14/21 11:27

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	0.0039	mg/L	06/01/21 21:03

- Qualifiers:**
- * Value may exceed the Acceptable Level
 - E Value exceeds the instrument calibration range
 - J Analyte detected below the PQL
 - P Prim./Conf. column %D or RPD exceeds limit
 - B Analyte detected in the associated Method Blank
 - H Holding times for preparation or analysis exceeded
 - ND Not Detected at the Practical Quantitation Limit (PQL)
 - S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.
 5854 Butternut Drive
 East Syracuse, NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Moravia School Dist.
Location:
Matrix: PWS

Client Sample ID: MFE99
Lab ID: 2107149-094A
Collection Date: 05/13/21 7:10
Date Received: 05/14/21 11:27

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	0.0079	mg/L	06/01/21 21:09

- Qualifiers:**
- * Value may exceed the Acceptable Level
 - E Value exceeds the instrument calibration range
 - J Analyte detected below the PQL
 - P Prim./Conf. column %D or RPD exceeds limit
 - B Analyte detected in the associated Method Blank
 - H Holding times for preparation or analysis exceeded
 - ND Not Detected at the Practical Quantitation Limit (PQL)
 - S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.
 5854 Butternut Drive
 East Syracuse, NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Moravia School Dist.
Location:
Matrix: PWS

Client Sample ID: MFE100
Lab ID: 2107149-095A
Collection Date: 05/13/21 7:10
Date Received: 05/14/21 11:27

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	0.0013	mg/L	06/01/21 21:11

- | | | |
|--------------------|--|---|
| Qualifiers: | * Value may exceed the Acceptable Level | B Analyte detected in the associated Method Blank |
| | E Value exceeds the instrument calibration range | H Holding times for preparation or analysis exceeded |
| | J Analyte detected below the PQL | ND Not Detected at the Practical Quantitation Limit (PQL) |
| | P Prim./Conf. column %D or RPD exceeds limit | S Spike Recovery outside accepted recovery limits |



Life Science Laboratories, Inc.
 5854 Butternut Drive
 East Syracuse , NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Moravia School Dist.
Location:
Matrix: PWS

Client Sample ID: MFE101
Lab ID: 2107149-096A
Collection Date: 05/13/21 7:10
Date Received: 05/14/21 11:27

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	0.0054	mg/L	06/01/21 21:13

- Qualifiers:**
- * Value may exceed the Acceptable Level
 - E Value exceeds the instrument calibration range
 - J Analyte detected below the PQL
 - P Prim./Conf. column %D or RPD exceeds limit
 - B Analyte detected in the associated Method Blank
 - H Holding times for preparation or analysis exceeded
 - ND Not Detected at the Practical Quantitation Limit (PQL)
 - S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.
 5854 Butternut Drive
 East Syracuse, NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Moravia School Dist.
Location:
Matrix: PWS

Client Sample ID: MFE102

Lab ID: 2107149-097A
Collection Date: 05/13/21 7:11
Date Received: 05/14/21 11:27

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	0.0037	mg/L	06/01/21 21:15

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.
 5854 Butternut Drive
 East Syracuse , NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Moravia School Dist.
Location:
Matrix: PWS

Client Sample ID: MFE103
Lab ID: 2107149-098A
Collection Date: 05/13/21 8:30
Date Received: 05/14/21 11:27

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	< 0.0010	mg/L	06/01/21 21:17

- Qualifiers:**
- * Value may exceed the Acceptable Level
 - E Value exceeds the instrument calibration range
 - J Analyte detected below the PQL
 - P Prim./Conf. column %D or RPD exceeds limit
 - B Analyte detected in the associated Method Blank
 - H Holding times for preparation or analysis exceeded
 - ND Not Detected at the Practical Quantitation Limit (PQL)
 - S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.
 5854 Butternut Drive
 East Syracuse, NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Moravia School Dist.
Location:
Matrix: PWS

Client Sample ID: MFE104
Lab ID: 2107149-099A
Collection Date: 05/13/21 8:30
Date Received: 05/14/21 11:27

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	0.0094	mg/L	06/01/21 21:23

- Qualifiers:**
- * Value may exceed the Acceptable Level
 - E Value exceeds the instrument calibration range
 - J Analyte detected below the PQL
 - P Prim./Conf. column %D or RPD exceeds limit
 - B Analyte detected in the associated Method Blank
 - H Holding times for preparation or analysis exceeded
 - ND Not Detected at the Practical Quantitation Limit (PQL)
 - S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS

Project: Moravia School Dist.

Location:

Matrix: PWS

Client Sample ID: MFE105

Lab ID: 2107149-100A

Collection Date: 05/13/21 8:30

Date Received: 05/14/21 11:27

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	0.012	mg/L	06/01/21 21:25

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.
 5854 Butternut Drive
 East Syracuse , NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Moravia School Dist.
Location:
Matrix: PWS

Client Sample ID: MFE106
Lab ID: 2107149-101A
Collection Date: 05/13/21 8:31
Date Received: 05/14/21 11:27

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	0.025 *	mg/L	06/01/21 21:27

- | | | |
|--------------------|--|---|
| Qualifiers: | * Value may exceed the Acceptable Level | B Analyte detected in the associated Method Blank |
| | E Value exceeds the instrument calibration range | H Holding times for preparation or analysis exceeded |
| | J Analyte detected below the PQL | ND Not Detected at the Practical Quantitation Limit (PQL) |
| | P Prim./Conf. column %D or RPD exceeds limit | S Spike Recovery outside accepted recovery limits |



Life Science Laboratories, Inc.
 5854 Butternut Drive
 East Syracuse , NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Moravia School Dist.
Location:
Matrix: PWS

Client Sample ID: MFE107

Lab ID: 2107149-102A
Collection Date: 05/13/21 8:31
Date Received: 05/14/21 11:27

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	0.0097	mg/L	06/01/21 21:29

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.
 5854 Butternut Drive
 East Syracuse , NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Moravia School Dist.
Location:
Matrix: PWS

Client Sample ID: MFE108
Lab ID: 2107149-103A
Collection Date: 05/13/21 8:31
Date Received: 05/14/21 11:27

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	0.0025	mg/L	06/01/21 21:31

- Qualifiers:**
- * Value may exceed the Acceptable Level
 - E Value exceeds the instrument calibration range
 - J Analyte detected below the PQL
 - P Prim./Conf. column %D or RPD exceeds limit
 - B Analyte detected in the associated Method Blank
 - H Holding times for preparation or analysis exceeded
 - ND Not Detected at the Practical Quantitation Limit (PQL)
 - S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.
 5854 Butternut Drive
 East Syracuse, NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Moravia School Dist.
Location:
Matrix: PWS

Client Sample ID: MFE109
Lab ID: 2107149-104A
Collection Date: 05/13/21 8:33
Date Received: 05/14/21 11:27

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	0.035 *	mg/L	06/10/21 13:47

- | | | |
|--------------------|--|---|
| Qualifiers: | * Value may exceed the Acceptable Level | B Analyte detected in the associated Method Blank |
| | E Value exceeds the instrument calibration range | H Holding times for preparation or analysis exceeded |
| | J Analyte detected below the PQL | ND Not Detected at the Practical Quantitation Limit (PQL) |
| | P Prim./Conf. column %D or RPD exceeds limit | S Spike Recovery outside accepted recovery limits |



Life Science Laboratories, Inc.
 5854 Butternut Drive
 East Syracuse, NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Moravia School Dist.
Location:
Matrix: PWS

Client Sample ID: MFE110
Lab ID: 2107149-105A
Collection Date: 05/13/21 8:33
Date Received: 05/14/21 11:27

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	0.060 *	mg/L	06/10/21 13:49

- Qualifiers:**
- * Value may exceed the Acceptable Level
 - E Value exceeds the instrument calibration range
 - J Analyte detected below the PQL
 - P Prim./Conf. column %D or RPD exceeds limit
 - B Analyte detected in the associated Method Blank
 - H Holding times for preparation or analysis exceeded
 - ND Not Detected at the Practical Quantitation Limit (PQL)
 - S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.
 5854 Butternut Drive
 East Syracuse, NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Moravia School Dist.
Location:
Matrix: PWS

Client Sample ID: MFE111
Lab ID: 2107149-106A
Collection Date: 05/13/21 8:33
Date Received: 05/14/21 11:27

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	0.0060	mg/L	06/01/21 21:33

- Qualifiers:**
- * Value may exceed the Acceptable Level
 - E Value exceeds the instrument calibration range
 - J Analyte detected below the PQL
 - P Prim./Conf. column %D or RPD exceeds limit
 - B Analyte detected in the associated Method Blank
 - H Holding times for preparation or analysis exceeded
 - ND Not Detected at the Practical Quantitation Limit (PQL)
 - S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.
 5854 Butternut Drive
 East Syracuse , NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Moravia School Dist.
Location:
Matrix: PWS

Client Sample ID: MFE112
Lab ID: 2107149-107A
Collection Date: 05/13/21 8:40
Date Received: 05/14/21 11:27

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	0.0032	mg/L	06/01/21 21:35

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.
 5854 Butternut Drive
 East Syracuse, NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Moravia School Dist.
Location:
Matrix: PWS

Client Sample ID: MFE113

Lab ID: 2107149-108A
Collection Date: 05/13/21 8:40
Date Received: 05/14/21 11:27

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	0.0045	mg/L	06/01/21 21:37

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.
5854 Butternut Drive
East Syracuse, NY 13057

2107149

Invoiced_Government

200

Chain of Custody Record

Client: <u>Morris School</u>		Telefax # (315) 445-1104		Contact Person: <u>Dzale</u>		ISL Project #:			
Address: <u>685 Main St</u>		Phone # <u>477-2670</u>		<u>315</u>		Client's Site I.D.:			
<u>Morris NY 13118</u>		Fax # <u>477-2260</u>		<u>224-9662</u>		Client's Project I.D.:			
LSL Sample Number	Client's Sample Identifications	Authorization:		Matrix	Preserv. Added	Containers # size/type	Analyses	Free Cl (mg/L)	Pres. Check
		Sample Date	Sample Time						
001A	MFE 01	5-13	6:30	PW	None	1 250 ml	Lead		<2
2	02		6:50						
3	03		6:30						
4	04		6:30						
5	05		6:30						
6	06		6:35						
7	07		6:55						
8	08		6:41						
9	09		6:41						
10	10		6:41						
11	11		6:48						
12	MFE 12		6:47						
13	MFE 13		6:44						
14	MFE 39	5-13	6:45						

Notes and Hazard Identifications: 107 Samples

Print Name: M. Longe Signature: [Signature] Date: 5-14 1126

Received By: [Signature]

Received for Lab By: [Signature] Date: 5/14/2001 1127

Shipment Method: Samples Preserved Upon Receipt at Lab

Samples Received Intact: Y N

219c



Life Science Laboratories, Inc.
5854 Butternut Drive
East Syracuse, NY 13057

2107149

Invoiced_Government

200

Chain of Custody Record

Telephone # (315) 445-1104

Phone # 497-2670

Client: Horans School

Address: 685 Mah St

Merous NY 13118

Contact Person: Date

3/5

284-9662

ISL Project #:

Client's Site I.D.:

Authorization:

ISL Sample Number	Client's Sample Identifications	Sample Date	Sample Time	Type		Matrix	Preserv. Added	Containers		Analyses	Free Cl (mg/L)	Pres. Check
				grab	comp.			#	size/type			
015A	MFE 15	5-13	10:00	X		PW	None	1	250 ml	Lead		✓
16	16		10:04	X				1				
17	17		10:06	X				1				
18	18		10:06	X				1				
19	19		10:07	X				1				
20	20		10:06	X				1				
21	21		10:03	X				1				
22	22		10:03	X				1				
23	23		10:03	X				1				
24	24		10:03	X				1				
25	25		10:05	X				1				
26	26		10:05	X				1				
27	27		10:05	X				1				
28	MFE 28	5-13	10:05	X				1				✓

Client's Project I.D.:


Notes and Hazard Identifications:

Custody Transfers		Date	Time
Sampled and Relinquished By:	Signature: <u>[Signature]</u>	5-14	11:25
Relinquished By:	Received By:		
Relinquished By:	Received for Lab By:	5/14/21	11:27

Shipment Method:

Samples Received Intact: Y N

21.9°C



Life Science Laboratories, Inc.
5854 Butternut Drive
East Syracuse, NY 13057

2107149

Invoiced_Government

200

Chain of Custody Record

Client: <u>Moravia School</u>		Telefax # (315) 445-1104		Contact Person: <u>Date</u>		LSL Project #:					
Address: <u>605 Main St</u>		Phone # <u>497-2670</u>		<u>3/5</u>		Client's Site I.D.:					
<u>Moravia NY 13119</u>		Fax # <u>497-2960</u>		<u>224-9662</u>		Client's Project I.D.:					
LSL Sample Number	Client's Sample Identifications	Authorization:			Matrix	Preserv. Added	Containers		Analyses	Free Cl (mg/L)	Pres. Check
		Sample Date	Sample Time	Type			#	size/type			
43A	MFE 45	5-13	646	X	PW	None	1	250 ml	Lead		<2
44	MFE 46		646	X			1				
45	MFE 47		646	X			1				
46	MFE 48		5:47	X			1				
47	MFE 50		6:47	X			1				
48			6:48	X			1				
49			6:48	X			1				
50			6:48	X			1				
51			6:48	X			1				
52			6:48	X			1				
53			6:50	X			1				
54			4:51	X			1				
55			6:56	X			1				
56			6:56	X			1				
57	MFE 51	5-13	6:50	X			1				

Notes and Hazard Identifications:

Custody Transfers		Date	Time
Sampled and Relinquished By:	Signature: <u>[Signature]</u>	5-14	11:25
Relinquished By:	Received By:		
Relinquished By:	Received for Lab By:	5/14/21	11:27
Shipment Method:		21.9°C	



Life Science Laboratories, Inc.
5854 Butternut Drive
East Syracuse, NY 13057

Chain of Custody Record

2107149

Invoiced_Government

200

Client: Moravia School LSL Project #: _____
 Address: 685 main st Client's Site I.D.: _____
Moravia NY 13118 224-9662

Contact Person: DAKE 315-224-9662

Telephone # (315) 445-1104 Phone # 497-2670
 Fax # 497-2260

LSL Sample Number	Client's Sample Identifications	Authorization:		Sample Date	Sample Time	Sample		Type	Matrix	Preserv. Added	Containers		Analyses	Free Cl (mg/L)	Pres. Check
		Sample Date	Sample Time			#	size/type								
0574	MFE 58	5/13	653			X			PW	None	1	250 ml	Lead		✓
58	MFE 59		653			X					1				
59	66		653			X					1				
60	61		653			X					1				
61	76		655			X					1				
62	77		655			X					1				
63	78		655			X					1				
64	79		651			X					1				
65	82		652			X					1				
66	83		657			X					1				
67	84		654			X					1				
68	MFE 75	5/13	657			X					1				
						X					1				
						X					1				

Notes and Hazard Identifications:

Custody Transfers

Sampled and Relinquished By: _____ Date: _____ Time: _____
 Print Name: M Washburn Signature: _____ Date: 5/14 Time: 1125

Relinquished By: _____ Received By: _____
 Relinquished By: _____ Received for Lab By: _____ Date: 5/14/21 Time: 1127

Shipment Method: _____ Samples Received Intact: Y N 21.9%

Chain of Custody Record

2107149

Invoiced_Government

200

Client: Moravia School Telephone # (315) 445-1900
 Address: 68 S Main St Phone # 977-7670
Moravia N.Y 13118 Fax # 977-2260

Contact Person: Dale LSL Project #:
3/5
844-962 Client's Site I.D.:

LSL Sample Number	Client's Sample Identifications	Authorization:		Sample Date	Sample Time	Type		Matrix	Preserv. Added	Containers # size/type	Analyses	Free Cl (mg/L)	Pres. Check
		Sample Date	Sample Time			grab	comp.						
069A	MFE 66	5-13	10:55	X		PW	None	1	250 mL	Lead		<2	
70	67		10:55	X				1					
71	68		10:55	X				1					
72	69		10:55	X				1					
73	70		10:57	X				1					
74	71		10:57	X				1					
75	72		10:57	X				1					
76	73		11	X				1					
77	75		11	X				1					
78	110		11:05	X				1					
79	117		11:05	X				1					
80	118		11:06	X				1					
81	119		11:06	X				1					
82	MFE 120	5-13	11:07	X				1					

Notes and Hazard Identifications:

Custody Transfers

Sampled and Relinquished By: M. Lamphre Signature: [Signature] Date: 5-14 Time: 11:05

Relinquished By: _____ Received By: _____

Relinquished By: _____ Received for Lab By: [Signature] Date: 5/14/21 Time: 11:27

Shipment Method: _____ Samples Received Intact: Y N Temperature: 21.9°C



Life Science Laboratories, Inc.

Date Printed:

6/3/21

Laboratory Analysis Report Prepared For Moravia School District

Client Project ID: Moravia School

LSL Project ID: 2106942

Dale
Moravia School District
685 Main St
Moravia, NY 13118

Phone: (315) 497-2670
FAX: (315) 497-2260

A copy of this report was sent to:

Sample ID: HS 08	LSL Sample ID: 2106942-001
Location:	Receive Date/Time: 05/12/21 11:20
Sampled: 05/11/21 9:50	Project Rec'd by: dcr1
Sampled By: ML	Matrix: PWS

Analytical Method	Prep Method	Prep Date	Analysis Date & Time	Analyst Initials
Analyte	Result Units			

(1) Lead Study

Number of Samples

81

MT

Please refer to the chain of custody form on the last page of this report for the detailed descriptions of where these samples were taken.

Life Science Laboratories, Inc. warrants, to the best of its knowledge and belief, the accuracy of the analytical test results contained in this report, but makes no other warranty, expressed or implied, especially no warranties of merchantability or fitness for a particular purpose. By the Client's acceptance and/or use of this report, the Client agrees that LSL is hereby released from any and all liabilities, claims, damages or causes of action affecting or which may affect the Client as regards to the results contained in this report. The Client further agrees that the only remedy available to the Client in the event of proven non-conformity with the above warranty shall be for LSL to re-perform the analytical test(s) at no charge to the Client. The data contained in this report are for the exclusive use of the Client to whom it is addressed, and the release of these data to any other party, or the use of the name, trademark or service mark of Life Science Laboratories, Inc. especially for the use of advertising to the general public, is strictly prohibited without express prior written consent of Life Science Laboratories, Inc. This report may only be reproduced in its entirety. No partial duplication is allowed. The Chain of Custody and the Sample Receipt documents submitted with these samples are considered by LSL to be an appendix of this report and may contain data qualifiers and specific information that pertains to the samples included in this report. The analytical result(s) in this report are only representative of the sample(s) submitted for analysis. LSL makes no claim of a sample's representativeness, or integrity, if sampling was not performed by LSL personnel.

LSL Central Lab
5854 Butternut Drive
East Syracuse, NY 13057
Tel. (315) 445-1900
Fax (315) 445-1104
NYS DOH ELAP #10248

LSL North Lab
131 St. Lawrence Avenue
Waddington, NY 13694
Tel. (315) 388-4476
Fax (315) 388-4061
NYS DOH ELAP #10900

LSL Finger Lakes Lab
16 N. Main St., PO Box 424
Wayland, NY 14572
Tel. (585) 213-4090
Fax (585) 213-4192
NYS DOH ELAP #11667

LSL Southern Tier Office
Cuba, NY
Tel. (585) 209-4032

LSL MidLakes Office
Canandaigua, NY
Tel. (585) 728-3320

Reviewed by:

Kristin E. Carpenter, Quality Staff

Date:

Analysis performed at: (1) LSL Central Lab, (2) LSL North Lab, (3) LSL Finger Lakes Lab



Life Science Laboratories, Inc.
 5854 Butternut Drive
 East Syracuse, NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Moravia School District
Location:
Matrix: PWS

Client Sample ID: HS 08
Lab ID: 2106942-001A
Collection Date: 05/11/21 9:50
Date Received: 05/12/21 11:20

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	0.0025	mg/L	06/01/21 12:30

- Qualifiers:**
- * Value may exceed the Acceptable Level
 - E Value exceeds the instrument calibration range
 - J Analyte detected below the PQL
 - P Prim./Conf. column %D or RPD exceeds limit
 - B Analyte detected in the associated Method Blank
 - H Holding times for preparation or analysis exceeded
 - ND Not Detected at the Practical Quantitation Limit (PQL)
 - S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.
 5854 Butternut Drive
 East Syracuse , NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Moravia School District
Location:
Matrix: PWS

Client Sample ID: HS 09

Lab ID: 2106942-002A
Collection Date: 05/11/21 9:50
Date Received: 05/12/21 11:20

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	0.0024	mg/L	06/01/21 12:32

- Qualifiers:**
- * Value may exceed the Acceptable Level
 - E Value exceeds the instrument calibration range
 - J Analyte detected below the PQL
 - P Prim./Conf. column %D or RPD exceeds limit
 - B Analyte detected in the associated Method Blank
 - H Holding times for preparation or analysis exceeded
 - ND Not Detected at the Practical Quantitation Limit (PQL.)
 - S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.
 5854 Butternut Drive
 East Syracuse, NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Moravia School District
Location:
Matrix: PWS

Client Sample ID: HS 12

Lab ID: 2106942-003A
Collection Date: 05/11/21 9:51
Date Received: 05/12/21 11:20

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS			
Lead	0.0019	EPA 200.8,Rev.5.4 mg/L	(EPA 200.2) 06/01/21 12:34

- Qualifiers:**
- * Value may exceed the Acceptable Level
 - E Value exceeds the instrument calibration range
 - J Analyte detected below the PQL
 - P Prim./Conf. column %D or RPD exceeds limit
 - B Analyte detected in the associated Method Blank
 - H Holding times for preparation or analysis exceeded
 - ND Not Detected at the Practical Quantitation Limit (PQL)
 - S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.

5854 Butternut Drive
East Syracuse , NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Moravia School District
Location:
Matrix: PWS

Client Sample ID: *HS 13*

Lab ID: 2106942-004A
Collection Date: 05/11/21 9:51
Date Received: 05/12/21 11:20

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	0.0041	mg/L	06/01/21 12:36

- Qualifiers:**
- * Value may exceed the Acceptable Level
 - E Value exceeds the instrument calibration range
 - J Analyte detected below the PQL
 - P Prim./Conf. column %D or RPD exceeds limit
 - B Analyte detected in the associated Method Blank
 - H Holding times for preparation or analysis exceeded
 - ND Not Detected at the Practical Quantitation Limit (PQL.)
 - S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.
 5854 Butternut Drive
 East Syracuse, NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Moravia School District
Location:
Matrix: PWS

Client Sample ID: *HS 14*

Lab ID: 2106942-005A
Collection Date: 05/11/21 9:51
Date Received: 05/12/21 11:20

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	0.027 *	mg/L	06/01/21 12:38

- Qualifiers:**
- * Value may exceed the Acceptable Level
 - E Value exceeds the instrument calibration range
 - J Analyte detected below the PQL
 - P Prim./Conf. column %D or RPD exceeds limit
 - B Analyte detected in the associated Method Blank
 - H Holding times for preparation or analysis exceeded
 - ND Not Detected at the Practical Quantitation Limit (PQL)
 - S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.
 5854 Butternut Drive
 East Syracuse , NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Moravia School District
Location:
Matrix: PWS

Client Sample ID: *HS 80*

Lab ID: 2106942-006A
Collection Date: 05/11/21 9:53
Date Received: 05/12/21 11:20

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	0.020 *	mg/L	06/01/21 12:40

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.
 5854 Butternut Drive
 East Syracuse, NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Moravia School District
Location:
Matrix: PWS

Client Sample ID: HS 81

Lab ID: 2106942-007A
Collection Date: 05/11/21 9:53
Date Received: 05/12/21 11:20

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	0.021 *	mg/L	06/01/21 12:46

- Qualifiers:**
- * Value may exceed the Acceptable Level
 - E Value exceeds the instrument calibration range
 - J Analyte detected below the PQL
 - P Prim./Conf. column %D or RPD exceeds limit
 - B Analyte detected in the associated Method Blank
 - H Holding times for preparation or analysis exceeded
 - ND Not Detected at the Practical Quantitation Limit (PQL)
 - S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.
 5854 Butternut Drive
 East Syracuse, NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Moravia School District
Location:
Matrix: PWS

Client Sample ID: *HS 82*

Lab ID: 2106942-008A
Collection Date: 05/11/21 9:53
Date Received: 05/12/21 11:20

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	0.014	mg/L	06/01/21 12:48

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.
 5854 Butternut Drive
 East Syracuse, NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Moravia School District
Location:
Matrix: PWS

Client Sample ID: HS 32

Lab ID: 2106942-009A
Collection Date: 05/11/21 9:54
Date Received: 05/12/21 11:20

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	0.034 *	mg/L	06/01/21 12:50

- Qualifiers:**
- * Value may exceed the Acceptable Level
 - E Value exceeds the instrument calibration range
 - J Analyte detected below the PQL
 - P Prim./Conf. column %D or RPD exceeds limit
 - B Analyte detected in the associated Method Blank
 - H Holding times for preparation or analysis exceeded
 - ND Not Detected at the Practical Quantitation Limit (PQL)
 - S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.
 5854 Butternut Drive
 East Syracuse, NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Moravia School District
Location:
Matrix: PWS

Client Sample ID: HS 20

Lab ID: 2106942-010A
Collection Date: 05/11/21 10:25
Date Received: 05/12/21 11:20

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	< 0.0010	mg/L	06/01/21 12:52

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.
 5854 Butternut Drive
 East Syracuse , NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Moravia School District
Location:
Matrix: PWS

Client Sample ID: *HS 21*
Lab ID: 2106942-011A
Collection Date: 05/11/21 10:25
Date Received: 05/12/21 11:20

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	< 0.0010	mg/L	06/01/21 12:54

- Qualifiers:**
- * Value may exceed the Acceptable Level
 - E Value exceeds the instrument calibration range
 - J Analyte detected below the PQL
 - P Prim./Conf. column %D or RPD exceeds limit
 - B Analyte detected in the associated Method Blank
 - H Holding times for preparation or analysis exceeded
 - ND Not Detected at the Practical Quantitation Limit (PQL)
 - S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.
 5854 Butternut Drive
 East Syracuse, NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Moravia School District
Location:
Matrix: PWS

Client Sample ID: HS 22

Lab ID: 2106942-012A
Collection Date: 05/11/21 10:25
Date Received: 05/12/21 11:20

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	0.0011	mg/L	06/01/21 13:00

- Qualifiers:**
- * Value may exceed the Acceptable Level
 - E Value exceeds the instrument calibration range
 - J Analyte detected below the PQL
 - P Prim./Conf. column %D or RPD exceeds limit
 - B Analyte detected in the associated Method Blank
 - H Holding times for preparation or analysis exceeded
 - ND Not Detected at the Practical Quantitation Limit (PQL)
 - S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS

Client Sample ID: *HS 23*

Project: Moravia School District

Location:

Lab ID: 2106942-013A

Matrix: PWS

Collection Date: 05/11/21 10:27

Date Received: 05/12/21 11:20

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	0.0015	mg/L	06/01/21 13:02

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.

5854 Butternut Drive

East Syracuse , NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS

Client Sample ID: HS 28

Project: Moravia School District

Location:

Lab ID: 2106942-014A

Matrix: PWS

Collection Date: 05/11/21 10:28

Date Received: 05/12/21 11:20

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	0.037 *	mg/L	06/01/21 13:04

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.
 5854 Butternut Drive
 East Syracuse, NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Moravia School District
Location:
Matrix: PWS

Client Sample ID: HS 29

Lab ID: 2106942-015A
Collection Date: 05/11/21 10:29
Date Received: 05/12/21 11:20

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	0.015	mg/L	06/01/21 13:10

Qualifiers:

* Value may exceed the Acceptable Level	B Analyte detected in the associated Method Blank
E Value exceeds the instrument calibration range	H Holding times for preparation or analysis exceeded
J Analyte detected below the PQL	ND Not Detected at the Practical Quantitation Limit (PQL)
P Prim./Conf. column %D or RPD exceeds limit	S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.

5854 Butternut Drive

East Syracuse , NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Moravia School District
Location:
Matrix: PWS

Client Sample ID: HS 30

Lab ID: 2106942-016A
Collection Date: 05/11/21 10:29
Date Received: 05/12/21 11:20

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	0.028 *	mg/L	06/01/21 13:12

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.

5854 Butternut Drive

East Syracuse , NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS

Client Sample ID: *HS 31*

Project: Moravia School District

Location:

Lab ID: 2106942-017A

Matrix: PWS

Collection Date: 05/11/21 10:29

Date Received: 05/12/21 11:20

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	0.010	mg/L	06/01/21 13:14

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.
 5854 Butternut Drive
 East Syracuse, NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Moravia School District
Location:
Matrix: PWS

Client Sample ID: HS 33

Lab ID: 2106942-018A
Collection Date: 05/11/21 10:31
Date Received: 05/12/21 11:20

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	0.0052	mg/L	06/01/21 13:16

- Qualifiers:**
- * Value may exceed the Acceptable Level
 - E Value exceeds the instrument calibration range
 - J Analyte detected below the PQL
 - P Prim./Conf. column %D or RPD exceeds limit
 - B Analyte detected in the associated Method Blank
 - H Holding times for preparation or analysis exceeded
 - ND Not Detected at the Practical Quantitation Limit (PQL)
 - S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.
 5854 Butternut Drive
 East Syracuse , NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Moravia School District
Location:
Matrix: PWS

Client Sample ID: HS 34

Lab ID: 2106942-019A
Collection Date: 05/11/21 10:31
Date Received: 05/12/21 11:20

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	0.017 *	mg/L	06/01/21 13:18

- Qualifiers:**
- * Value may exceed the Acceptable Level
 - E Value exceeds the instrument calibration range
 - J Analyte detected below the PQL
 - P Prim./Conf. column %D or RPD exceeds limit
 - B Analyte detected in the associated Method Blank
 - H Holding times for preparation or analysis exceeded
 - ND Not Detected at the Practical Quantitation Limit (PQL)
 - S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.
 5854 Butternut Drive
 East Syracuse , NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Moravia School District
Location:
Matrix: PWS

Client Sample ID: HS 35

Lab ID: 2106942-020A
Collection Date: 05/11/21 10:31
Date Received: 05/12/21 11:20

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	0.011	mg/L	06/01/21 13:20

- Qualifiers:**
- * Value may exceed the Acceptable Level
 - E Value exceeds the instrument calibration range
 - J Analyte detected below the PQL
 - P Prim./Conf. column %D or RPD exceeds limit
 - B Analyte detected in the associated Method Blank
 - H Holding times for preparation or analysis exceeded
 - ND Not Detected at the Practical Quantitation Limit (PQL)
 - S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.
 5854 Butternut Drive
 East Syracuse, NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Moravia School District
Location:
Matrix: PWS

Client Sample ID: HS 36

Lab ID: 2106942-021A
Collection Date: 05/11/21 10:31
Date Received: 05/12/21 11:20

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	0.020 *	mg/L	06/01/21 13:22

- Qualifiers:**
- * Value may exceed the Acceptable Level
 - E Value exceeds the instrument calibration range
 - J Analyte detected below the PQL
 - P Prim./Conf. column %D or RPD exceeds limit
 - B Analyte detected in the associated Method Blank
 - H Holding times for preparation or analysis exceeded
 - ND Not Detected at the Practical Quantitation Limit (PQL)
 - S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.

5854 Butternut Drive

East Syracuse , NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS

Project: Moravia School District

Location:

Matrix: PWS

Client Sample ID: *HS PE Office*

Lab ID: 2106942-022A

Collection Date: 05/11/21 10:42

Date Received: 05/12/21 11:20

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	0.0030	mg/L	06/01/21 13:24

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.
 5854 Butternut Drive
 East Syracuse , NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Moravia School District
Location:
Matrix: PWS

Client Sample ID: *HS Boys LR2*

Lab ID: 2106942-023A
Collection Date: 05/11/21 10:42
Date Received: 05/12/21 11:20

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	0.012	mg/L	05/21/21 16:45

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.

5854 Butternut Drive

East Syracuse , NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS

Project: Moravia School District

Location:

Matrix: PWS

Client Sample ID: *HS Boys LR*

Lab ID: 2106942-024A

Collection Date: 05/11/21 10:42

Date Received: 05/12/21 11:20

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	0.017 *	mg/L	06/01/21 13:26

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.
 5854 Butternut Drive
 East Syracuse , NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Moravia School District
Location:
Matrix: PWS

Client Sample ID: *HS Conf*

Lab ID: 2106942-025A
Collection Date: 05/11/21 10:43
Date Received: 05/12/21 11:20

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	0.0035	mg/L	06/01/21 13:28

- Qualifiers:**
- * Value may exceed the Acceptable Level
 - E Value exceeds the instrument calibration range
 - J Analyte detected below the PQL
 - P Prim./Conf. column %D or RPD exceeds limit
 - B Analyte detected in the associated Method Blank
 - H Holding times for preparation or analysis exceeded
 - ND Not Detected at the Practical Quantitation Limit (PQL)
 - S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.

5854 Butternut Drive

East Syracuse , NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS

Project: Moravia School District

Location:

Matrix: PWS

Client Sample ID: HS 59

Lab ID: 2106942-026A

Collection Date: 05/11/21 11:06

Date Received: 05/12/21 11:20

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	0.0011	mg/L	06/01/21 13:34

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.

5854 Butternut Drive

East Syracuse , NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS

Project: Moravia School District

Location:

Matrix: PWS

Client Sample ID: HS 60

Lab ID: 2106942-027A

Collection Date: 05/11/21 11:06

Date Received: 05/12/21 11:20

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	0.0011	mg/L	06/01/21 13:36

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.

5854 Butternut Drive
East Syracuse , NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Moravia School District
Location:
Matrix: PWS

Client Sample ID: *HS 61*
Lab ID: 2106942-028A
Collection Date: 05/11/21 11:06
Date Received: 05/12/21 11:20

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	0.0014	mg/L	06/01/21 13:38

- Qualifiers:**
- * Value may exceed the Acceptable Level
 - E Value exceeds the instrument calibration range
 - J Analyte detected below the PQL
 - P Prim./Conf. column %D or RPD exceeds limit
 - B Analyte detected in the associated Method Blank
 - H Holding times for preparation or analysis exceeded
 - ND Not Detected at the Practical Quantitation Limit (PQL)
 - S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.
 5854 Butternut Drive
 East Syracuse, NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Moravia School District
Location:
Matrix: PWS

Client Sample ID: *HS 62*

Lab ID: 2106942-029A
Collection Date: 05/11/21 11:06
Date Received: 05/12/21 11:20

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	< 0.0010	mg/L	06/01/21 13:40

- Qualifiers:**
- * Value may exceed the Acceptable Level
 - E Value exceeds the instrument calibration range
 - J Analyte detected below the PQL
 - P Prim./Conf. column %D or RPD exceeds limit
 - B Analyte detected in the associated Method Blank
 - H Holding times for preparation or analysis exceeded
 - ND Not Detected at the Practical Quantitation Limit (PQL)
 - S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.
 5854 Butternut Drive
 East Syracuse , NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Moravia School District
Location:
Matrix: PWS

Client Sample ID: HS 63

Lab ID: 2106942-030A
Collection Date: 05/11/21 11:06
Date Received: 05/12/21 11:20

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	0.0015	mg/L	06/01/21 13:42

- Qualifiers:**
- * Value may exceed the Acceptable Level
 - E Value exceeds the instrument calibration range
 - J Analyte detected below the PQL
 - P Prim./Conf. column %D or RPD exceeds limit
 - B Analyte detected in the associated Method Blank
 - H Holding times for preparation or analysis exceeded
 - ND Not Detected at the Practical Quantitation Limit (PQL)
 - S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.

5854 Butternut Drive

East Syracuse , NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS

Client Sample ID: *HS 64*

Project: Moravia School District

Location:

Lab ID: 2106942-031A

Matrix: PWS

Collection Date: 05/11/21 11:07

Date Received: 05/12/21 11:20

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	< 0.0010	mg/L	06/01/21 13:44

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.
 5854 Butternut Drive
 East Syracuse , NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Moravia School District
Location:
Matrix: PWS

Client Sample ID: HS 65

Lab ID: 2106942-032A
Collection Date: 05/11/21 11:08
Date Received: 05/12/21 11:20

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	0.0027	mg/L	06/01/21 13:46

- Qualifiers:**
- * Value may exceed the Acceptable Level
 - E Value exceeds the instrument calibration range
 - J Analyte detected below the PQL
 - P Prim./Conf. column %D or RPD exceeds limit
 - B Analyte detected in the associated Method Blank
 - H Holding times for preparation or analysis exceeded
 - ND Not Detected at the Practical Quantitation Limit (PQL)
 - S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.
 5854 Butternut Drive
 East Syracuse , NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Moravia School District
Location:
Matrix: PWS

Client Sample ID: *HS 102 Fountain*

Lab ID: 2106942-033A
Collection Date: 05/11/21 11:08
Date Received: 05/12/21 11:20

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	0.0016	mg/L	06/01/21 13:52

- Qualifiers:**
- * Value may exceed the Acceptable Level
 - E Value exceeds the instrument calibration range
 - J Analyte detected below the PQL
 - P Prim./Conf. column %D or RPD exceeds limit
 - B Analyte detected in the associated Method Blank
 - H Holding times for preparation or analysis exceeded
 - ND Not Detected at the Practical Quantitation Limit (PQL)
 - S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.

5854 Butternut Drive

East Syracuse , NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS

Client Sample ID: *HS Art Room 1*

Project: Moravia School District

Location:

Lab ID: 2106942-034A

Matrix: PWS

Collection Date: 05/11/21 11:08

Date Received: 05/12/21 11:20

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	0.011	mg/L	06/01/21 13:58

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.

5854 Butternut Drive

East Syracuse , NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Moravia School District
Location:
Matrix: PWS

Client Sample ID: *HS Art Room 2*

Lab ID: 2106942-035A
Collection Date: 05/11/21 11:08
Date Received: 05/12/21 11:20

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	< 0.0010	mg/L	06/01/21 14:00

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.
 5854 Butternut Drive
 East Syracuse , NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Moravia School District
Location:
Matrix: PWS

Client Sample ID: HS 66

Lab ID: 2106942-036A
Collection Date: 05/11/21 11:23
Date Received: 05/12/21 11:20

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	0.0060	mg/L	06/01/21 14:02

- Qualifiers:**
- * Value may exceed the Acceptable Level
 - E Value exceeds the instrument calibration range
 - J Analyte detected below the PQL
 - P Prim./Conf. column %D or RPD exceeds limit
 - B Analyte detected in the associated Method Blank
 - H Holding times for preparation or analysis exceeded
 - ND Not Detected at the Practical Quantitation Limit (PQL)
 - S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.
 5854 Butternut Drive
 East Syracuse , NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Moravia School District
Location:
Matrix: PWS

Client Sample ID: HS 67

Lab ID: 2106942-037A
Collection Date: 05/11/21 11:23
Date Received: 05/12/21 11:20

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	0.0055	mg/L	06/01/21 14:04

- Qualifiers:**
- * Value may exceed the Acceptable Level
 - E Value exceeds the instrument calibration range
 - J Analyte detected below the PQL
 - P Prim./Conf. column %D or RPD exceeds limit
 - B Analyte detected in the associated Method Blank
 - H Holding times for preparation or analysis exceeded
 - ND Not Detected at the Practical Quantitation Limit (PQL)
 - S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.

5854 Butternut Drive
East Syracuse, NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Moravia School District
Location:
Matrix: PWS

Client Sample ID: HS 68

Lab ID: 2106942-038A
Collection Date: 05/11/21 11:23
Date Received: 05/12/21 11:20

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	0.0029	mg/L	06/01/21 14:06

- Qualifiers:**
- * Value may exceed the Acceptable Level
 - E Value exceeds the instrument calibration range
 - J Analyte detected below the PQL
 - P Prim./Conf. column %D or RPD exceeds limit
 - B Analyte detected in the associated Method Blank
 - H Holding times for preparation or analysis exceeded
 - ND Not Detected at the Practical Quantitation Limit (PQL)
 - S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.

5854 Butternut Drive

East Syracuse , NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Moravia School District
Location:
Matrix: PWS

Client Sample ID: HS 69

Lab ID: 2106942-039A
Collection Date: 05/11/21 11:23
Date Received: 05/12/21 11:20

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	0.0016	mg/L	06/01/21 14:08

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS

Project: Moravia School District

Location:

Matrix: PWS

Client Sample ID: *HS Wood 1*

Lab ID: 2106942-040A

Collection Date: 05/11/21 11:25

Date Received: 05/12/21 11:20

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	0.0044	mg/L	06/01/21 14:10

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.

5854 Butternut Drive

East Syracuse , NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS

Client Sample ID: *HS Wood 2*

Project: Moravia School District

Location:

Lab ID: 2106942-041A

Matrix: PWS

Collection Date: 05/11/21 11:25

Date Received: 05/12/21 11:20

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	0.0043	mg/L	06/01/21 14:12

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.
 5854 Butternut Drive
 East Syracuse , NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Moravia School District
Location:
Matrix: PWS

Client Sample ID: HS 76

Lab ID: 2106942-042A
Collection Date: 05/11/21 11:38
Date Received: 05/12/21 11:20

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	0.0059	mg/L	06/01/21 14:14

- Qualifiers:**
- * Value may exceed the Acceptable Level
 - E Value exceeds the instrument calibration range
 - J Analyte detected below the PQL
 - P Prim./Conf. column %D or RPD exceeds limit
 - B Analyte detected in the associated Method Blank
 - H Holding times for preparation or analysis exceeded
 - ND Not Detected at the Practical Quantitation Limit (PQL)
 - S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Moravia School District
Location:
Matrix: PWS

Client Sample ID: HS 75
Lab ID: 2106942-043A
Collection Date: 05/11/21 11:38
Date Received: 05/12/21 11:20

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	0.0032	mg/L	06/01/21 14:16

- Qualifiers:**
- * Value may exceed the Acceptable Level
 - E Value exceeds the instrument calibration range
 - J Analyte detected below the PQL
 - P Prim./Conf. column %D or RPD exceeds limit
 - B Analyte detected in the associated Method Blank
 - H Holding times for preparation or analysis exceeded
 - ND Not Detected at the Practical Quantitation Limit (PQL)
 - S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.

5854 Butternut Drive

East Syracuse , NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Moravia School District
Location:
Matrix: PWS

Client Sample ID: HS 70

Lab ID: 2106942-044A
Collection Date: 05/11/21 11:37
Date Received: 05/12/21 11:20

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	< 0.0010	mg/L	06/01/21 14:22

- Qualifiers:**
- * Value may exceed the Acceptable Level
 - E Value exceeds the instrument calibration range
 - J Analyte detected below the PQL
 - P Prim./Conf. column %D or RPD exceeds limit
 - B Analyte detected in the associated Method Blank
 - H Holding times for preparation or analysis exceeded
 - ND Not Detected at the Practical Quantitation Limit (PQL)
 - S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.

5854 Butternut Drive

East Syracuse , NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS

Client Sample ID: HS 71

Project: Moravia School District

Location:

Lab ID: 2106942-045A

Matrix: PWS

Collection Date: 05/11/21 11:41

Date Received: 05/12/21 11:20

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	0.0026	mg/L	06/01/21 14:24

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.

5854 Butternut Drive
East Syracuse, NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Moravia School District
Location:
Matrix: PWS

Client Sample ID: HS 72
Lab ID: 2106942-046A
Collection Date: 05/11/21 11:41
Date Received: 05/12/21 11:20

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	0.0068	mg/L	06/01/21 14:26

- Qualifiers:**
- * Value may exceed the Acceptable Level
 - E Value exceeds the instrument calibration range
 - J Analyte detected below the PQL
 - P Prim./Conf. column %D or RPD exceeds limit
 - B Analyte detected in the associated Method Blank
 - H Holding times for preparation or analysis exceeded
 - ND Not Detected at the Practical Quantitation Limit (PQL)
 - S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.
 5854 Butternut Drive
 East Syracuse , NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Moravia School District
Location:
Matrix: PWS

Client Sample ID: HS 73
Lab ID: 2106942-047A
Collection Date: 05/11/21 11:41
Date Received: 05/12/21 11:20

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	0.017 *	mg/L	06/01/21 14:28

- Qualifiers:**
- * Value may exceed the Acceptable Level
 - E Value exceeds the instrument calibration range
 - J Analyte detected below the PQL
 - P Prim./Conf. column %D or RPD exceeds limit
 - B Analyte detected in the associated Method Blank
 - H Holding times for preparation or analysis exceeded
 - ND Not Detected at the Practical Quantitation Limit (PQL)
 - S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.

5854 Butternut Drive

East Syracuse , NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS

Client Sample ID: *HS 74*

Project: Moravia School District

Location:

Lab ID: 2106942-048A

Matrix: PWS

Collection Date: 05/11/21 11:41

Date Received: 05/12/21 11:20

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	0.0077	mg/L	06/01/21 14:30

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.

5854 Butternut Drive
East Syracuse , NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Moravia School District
Location:
Matrix: PWS

Client Sample ID: HS 01

Lab ID: 2106942-049A
Collection Date: 05/12/21 6:41
Date Received: 05/12/21 11:20

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	0.036 *	mg/L	05/21/21 16:49

- Qualifiers:**
- * Value may exceed the Acceptable Level
 - E Value exceeds the instrument calibration range
 - J Analyte detected below the PQL
 - P Prim./Conf. column %D or RPD exceeds limit
 - B Analyte detected in the associated Method Blank
 - H Holding times for preparation or analysis exceeded
 - ND Not Detected at the Practical Quantitation Limit (PQL)
 - S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.

5854 Butternut Drive

East Syracuse , NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS

Project: Moravia School District

Location:

Matrix: PWS

Client Sample ID: HS 02

Lab ID: 2106942-050A

Collection Date: 05/12/21 6:41

Date Received: 05/12/21 11:20

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	0.0011	mg/L	06/01/21 14:32

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.
 5854 Butternut Drive
 East Syracuse, NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Moravia School District
Location:
Matrix: PWS

Client Sample ID: HS 03

Lab ID: 2106942-051A
Collection Date: 05/12/21 6:41
Date Received: 05/12/21 11:20

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	0.0012	mg/L	06/01/21 14:34

- Qualifiers:**
- * Value may exceed the Acceptable Level
 - E Value exceeds the instrument calibration range
 - J Analyte detected below the PQL
 - P Prim./Conf. column %D or RPD exceeds limit
 - B Analyte detected in the associated Method Blank
 - H Holding times for preparation or analysis exceeded
 - ND Not Detected at the Practical Quantitation Limit (PQL)
 - S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.
 5854 Butternut Drive
 East Syracuse, NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Moravia School District
Location:
Matrix: PWS

Client Sample ID: HS 04

Lab ID: 2106942-052A
Collection Date: 05/12/21 6:41
Date Received: 05/12/21 11:20

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	0.0013	mg/L	06/01/21 14:36

- Qualifiers:**
- * Value may exceed the Acceptable Level
 - E Value exceeds the instrument calibration range
 - J Analyte detected below the PQL
 - P Prim./Conf. column %D or RPD exceeds limit
 - B Analyte detected in the associated Method Blank
 - H Holding times for preparation or analysis exceeded
 - ND Not Detected at the Practical Quantitation Limit (PQL)
 - S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.
 5854 Butternut Drive
 East Syracuse, NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Moravia School District
Location:
Matrix: PWS

Client Sample ID: HS 07

Lab ID: 2106942-053A
Collection Date: 05/12/21 6:42
Date Received: 05/12/21 11:20

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	0.0016	mg/L	06/01/21 14:41

Qualifiers:

* Value may exceed the Acceptable Level	B Analyte detected in the associated Method Blank
E Value exceeds the instrument calibration range	H Holding times for preparation or analysis exceeded
J Analyte detected below the PQL	ND Not Detected at the Practical Quantitation Limit (PQL)
P Prim./Conf. column %D or RPD exceeds limit	S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.
 5854 Butternut Drive
 East Syracuse , NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Moravia School District
Location:
Matrix: PWS

Client Sample ID: HS 06
Lab ID: 2106942-054A
Collection Date: 05/12/21 6:42
Date Received: 05/12/21 11:20

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	0.0014	mg/L	06/01/21 14:51

- Qualifiers:**
- * Value may exceed the Acceptable Level
 - E Value exceeds the instrument calibration range
 - J Analyte detected below the PQL
 - P Prim./Conf. column %D or RPD exceeds limit
 - B Analyte detected in the associated Method Blank
 - H Holding times for preparation or analysis exceeded
 - ND Not Detected at the Practical Quantitation Limit (PQL)
 - S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.
 5854 Butternut Drive
 East Syracuse , NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Moravia School District
Location:
Matrix: PWS

Client Sample ID: *HS 19*

Lab ID: 2106942-055A
Collection Date: 05/12/21 6:43
Date Received: 05/12/21 11:20

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	0.0083	mg/L	06/01/21 14:53

- Qualifiers:**
- * Value may exceed the Acceptable Level
 - E Value exceeds the instrument calibration range
 - J Analyte detected below the PQL
 - P Prim./Conf. column %D or RPD exceeds limit
 - B Analyte detected in the associated Method Blank
 - H Holding times for preparation or analysis exceeded
 - ND Not Detected at the Practical Quantitation Limit (PQL)
 - S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.
 5854 Butternut Drive
 East Syracuse , NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Moravia School District
Location:
Matrix: PWS

Client Sample ID: HS 05

Lab ID: 2106942-056A
Collection Date: 05/12/21 6:43
Date Received: 05/12/21 11:20

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	0.0011	mg/L	06/01/21 14:55

- Qualifiers:**
- * Value may exceed the Acceptable Level
 - E Value exceeds the instrument calibration range
 - J Analyte detected below the PQL
 - P Prim./Conf. column %D or RPD exceeds limit
 - B Analyte detected in the associated Method Blank
 - H Holding times for preparation or analysis exceeded
 - ND Not Detected at the Practical Quantitation Limit (PQL)
 - S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.
 5854 Butternut Drive
 East Syracuse , NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Moravia School District
Location:
Matrix: PWS

Client Sample ID: MS-WF

Lab ID: 2106942-057A
Collection Date: 05/12/21 6:45
Date Received: 05/12/21 11:20

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	< 0.0010	mg/L	06/01/21 14:57

- Qualifiers:**
- * Value may exceed the Acceptable Level
 - E Value exceeds the instrument calibration range
 - J Analyte detected below the PQL
 - P Prim./Conf. column %D or RPD exceeds limit
 - B Analyte detected in the associated Method Blank
 - H Holding times for preparation or analysis exceeded
 - ND Not Detected at the Practical Quantitation Limit (PQL)
 - S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.
 5854 Butternut Drive
 East Syracuse , NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Moravia School District
Location:
Matrix: PWS

Client Sample ID: HS 015
Lab ID: 2106942-058A
Collection Date: 05/12/21 6:53
Date Received: 05/12/21 11:20

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	0.010	mg/L	06/01/21 14:59

- Qualifiers:**
- * Value may exceed the Acceptable Level
 - E Value exceeds the instrument calibration range
 - J Analyte detected below the PQL
 - P Prim./Conf. column %D or RPD exceeds limit
 - B Analyte detected in the associated Method Blank
 - H Holding times for preparation or analysis exceeded
 - ND Not Detected at the Practical Quantitation Limit (PQL)
 - S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.

5854 Butternut Drive

East Syracuse , NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS

Project: Moravia School District

Location:

Matrix: PWS

Client Sample ID: HS-16

Lab ID: 2106942-059A

Collection Date: 05/12/21 6:53

Date Received: 05/12/21 11:20

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	0.0041	mg/L	06/01/21 15:01

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.
 5854 Butternut Drive
 East Syracuse , NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Moravia School District
Location:
Matrix: PWS

Client Sample ID: HS 17

Lab ID: 2106942-060A
Collection Date: 05/12/21 6:53
Date Received: 05/12/21 11:20

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	0.0054	mg/L	06/01/21 15:03

- Qualifiers:**
- * Value may exceed the Acceptable Level
 - E Value exceeds the instrument calibration range
 - J Analyte detected below the PQL
 - P Prim./Conf. column %D or RPD exceeds limit
 - B Analyte detected in the associated Method Blank
 - H Holding times for preparation or analysis exceeded
 - ND Not Detected at the Practical Quantitation Limit (PQL)
 - S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.
 5854 Butternut Drive
 East Syracuse , NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Moravia School District
Location:
Matrix: PWS

Client Sample ID: HS 18

Lab ID: 2106942-061A
Collection Date: 05/12/21 6:53
Date Received: 05/12/21 11:20

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	0.0024	mg/L	06/01/21 15:05

- Qualifiers:**
- * Value may exceed the Acceptable Level
 - E Value exceeds the instrument calibration range
 - J Analyte detected below the PQL
 - P Prim./Conf. column %D or RPD exceeds limit
 - B Analyte detected in the associated Method Blank
 - H Holding times for preparation or analysis exceeded
 - ND Not Detected at the Practical Quantitation Limit (PQL)
 - S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.

5854 Butternut Drive

East Syracuse , NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS

Client Sample ID: HS 24

Project: Moravia School District

Location:

Lab ID: 2106942-062A

Matrix: PWS

Collection Date: 05/12/21 6:38

Date Received: 05/12/21 11:20

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	0.0068	mg/L	06/01/21 15:07

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.
 5854 Butternut Drive
 East Syracuse, NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Moravia School District
Location:
Matrix: PWS

Client Sample ID: HS 27

Lab ID: 2106942-063A
Collection Date: 05/12/21 7:00
Date Received: 05/12/21 11:20

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	0.014	mg/L	06/01/21 15:13

- Qualifiers:**
- * Value may exceed the Acceptable Level
 - E Value exceeds the instrument calibration range
 - J Analyte detected below the PQL
 - P Prim./Conf. column %D or RPD exceeds limit
 - B Analyte detected in the associated Method Blank
 - H Holding times for preparation or analysis exceeded
 - ND Not Detected at the Practical Quantitation Limit (PQL)
 - S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.
 5854 Butternut Drive
 East Syracuse , NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Moravia School District
Location:
Matrix: PWS

Client Sample ID: HS 25

Lab ID: 2106942-064A
Collection Date: 05/12/21 7:02
Date Received: 05/12/21 11:20

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	0.027 *	mg/L	06/01/21 15:15

- Qualifiers:**
- * Value may exceed the Acceptable Level
 - E Value exceeds the instrument calibration range
 - J Analyte detected below the PQL
 - P Prim./Conf. column %D or RPD exceeds limit
 - B Analyte detected in the associated Method Blank
 - H Holding times for preparation or analysis exceeded
 - ND Not Detected at the Practical Quantitation Limit (PQL)
 - S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.

5854 Butternut Drive

East Syracuse , NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS

Client Sample ID: *HS 51*

Project: Moravia School District

Location:

Lab ID: 2106942-065A

Matrix: PWS

Collection Date: 05/12/21 7:12

Date Received: 05/12/21 11:20

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	0.0068	mg/L	06/01/21 15:17

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.

5854 Butternut Drive

East Syracuse , NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS

Client Sample ID: HS 52

Project: Moravia School District

Location:

Lab ID: 2106942-066A

Matrix: PWS

Collection Date: 05/12/21 7:12

Date Received: 05/12/21 11:20

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	0.010	mg/L	06/01/21 15:19

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.
 5854 Butternut Drive
 East Syracuse , NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Moravia School District
Location:
Matrix: PWS

Client Sample ID: HS 53

Lab ID: 2106942-067A
Collection Date: 05/12/21 7:12
Date Received: 05/12/21 11:20

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	0.013	mg/L	06/01/21 15:21

- Qualifiers:**
- * Value may exceed the Acceptable Level
 - E Value exceeds the instrument calibration range
 - J Analyte detected below the PQL
 - P Prim./Conf. column %D or RPD exceeds limit
 - B Analyte detected in the associated Method Blank
 - H Holding times for preparation or analysis exceeded
 - ND Not Detected at the Practical Quantitation Limit (PQL)
 - S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.
 5854 Butternut Drive
 East Syracuse , NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Moravia School District
Location:
Matrix: PWS

Client Sample ID: HS 54
Lab ID: 2106942-068A
Collection Date: 05/12/21 7:12
Date Received: 05/12/21 11:20

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	0.0030	mg/L	06/01/21 15:23

- Qualifiers:**
- * Value may exceed the Acceptable Level
 - E Value exceeds the instrument calibration range
 - J Analyte detected below the PQL
 - P Prim./Conf. column %D or RPD exceeds limit
 - B Analyte detected in the associated Method Blank
 - H Holding times for preparation or analysis exceeded
 - ND Not Detected at the Practical Quantitation Limit (PQL)
 - S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.

5854 Butternut Drive

East Syracuse , NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS

Client Sample ID: HS 55

Project: Moravia School District

Location:

Lab ID: 2106942-069A

Matrix: PWS

Collection Date: 05/12/21 7:14

Date Received: 05/12/21 11:20

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	< 0.0010	mg/L	06/01/21 15:25

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.
 5854 Butternut Drive
 East Syracuse , NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Moravia School District
Location:
Matrix: PWS

Client Sample ID: HS 56

Lab ID: 2106942-070A
Collection Date: 05/12/21 7:16
Date Received: 05/12/21 11:20

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	0.0016	mg/L	06/01/21 15:27

- Qualifiers:**
- * Value may exceed the Acceptable Level
 - E Value exceeds the instrument calibration range
 - J Analyte detected below the PQL
 - P Prim./Conf. column %D or RPD exceeds limit
 - B Analyte detected in the associated Method Blank
 - H Holding times for preparation or analysis exceeded
 - ND Not Detected at the Practical Quantitation Limit (PQL)
 - S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS

Project: Moravia School District

Location:

Matrix: PWS

Client Sample ID: HS 50

Lab ID: 2106942-071A

Collection Date: 05/12/21 7:26

Date Received: 05/12/21 11:20

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	< 0.0010	mg/L	06/01/21 15:29

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.
 5854 Butternut Drive
 East Syracuse , NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Moravia School District
Location:
Matrix: PWS

Client Sample ID: HS 49

Lab ID: 2106942-072A
Collection Date: 05/12/21 7:28
Date Received: 05/12/21 11:20

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	0.0011	mg/L	06/01/21 15:31

- Qualifiers:**
- * Value may exceed the Acceptable Level
 - E Value exceeds the instrument calibration range
 - J Analyte detected below the PQL
 - P Prim./Conf. column %D or RPD exceeds limit
 - B Analyte detected in the associated Method Blank
 - H Holding times for preparation or analysis exceeded
 - ND Not Detected at the Practical Quantitation Limit (PQL)
 - S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.
 5854 Butternut Drive
 East Syracuse , NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Moravia School District
Location:
Matrix: PWS

Client Sample ID: HS 47

Lab ID: 2106942-073A
Collection Date: 05/12/21 7:30
Date Received: 05/12/21 11:20

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	0.0018	mg/L	06/01/21 16:31

- Qualifiers:**
- * Value may exceed the Acceptable Level
 - E Value exceeds the instrument calibration range
 - J Analyte detected below the PQL
 - P Prim./Conf. column %D or RPD exceeds limit
 - B Analyte detected in the associated Method Blank
 - H Holding times for preparation or analysis exceeded
 - ND Not Detected at the Practical Quantitation Limit (PQL)
 - S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.

5854 Butternut Drive

East Syracuse , NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Moravia School District
Location:
Matrix: PWS

Client Sample ID: HS 48

Lab ID: 2106942-074A
Collection Date: 05/12/21 7:30
Date Received: 05/12/21 11:20

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	0.0013	mg/L	06/01/21 16:37

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.
 5854 Butternut Drive
 East Syracuse , NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Moravia School District
Location:
Matrix: PWS

Client Sample ID: HS 46

Lab ID: 2106942-075A
Collection Date: 05/12/21 7:30
Date Received: 05/12/21 11:20

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	0.0013	mg/L	06/01/21 16:39

- Qualifiers:**
- * Value may exceed the Acceptable Level
 - E Value exceeds the instrument calibration range
 - J Analyte detected below the PQL
 - P Prim./Conf. column %D or RPD exceeds limit
 - B Analyte detected in the associated Method Blank
 - H Holding times for preparation or analysis exceeded
 - ND Not Detected at the Practical Quantitation Limit (PQL)
 - S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.

5854 Butternut Drive

East Syracuse , NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS

Client Sample ID: HS 45

Project: Moravia School District

Location:

Lab ID: 2106942-076A

Matrix: PWS

Collection Date: 05/12/21 7:31

Date Received: 05/12/21 11:20

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	0.0012	mg/L	06/01/21 16:41

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.

5854 Butternut Drive

East Syracuse , NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS

Project: Moravia School District

Location:

Matrix: PWS

Client Sample ID: HS 041

Lab ID: 2106942-077A

Collection Date: 05/12/21 7:42

Date Received: 05/12/21 11:20

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	0.0052	mg/L	06/01/21 16:43

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.
 5854 Butternut Drive
 East Syracuse , NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Moravia School District
Location:
Matrix: PWS

Client Sample ID: HS 042

Lab ID: 2106942-078A
Collection Date: 05/12/21 7:42
Date Received: 05/12/21 11:20

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	0.0037	mg/L	06/01/21 16:45

- Qualifiers:**
- * Value may exceed the Acceptable Level
 - E Value exceeds the instrument calibration range
 - J Analyte detected below the PQL
 - P Prim./Conf. column %D or RPD exceeds limit
 - B Analyte detected in the associated Method Blank
 - H Holding times for preparation or analysis exceeded
 - ND Not Detected at the Practical Quantitation Limit (PQL)
 - S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.
 5854 Butternut Drive
 East Syracuse , NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Moravia School District
Location:
Matrix: PWS

Client Sample ID: HS 043
Lab ID: 2106942-079A
Collection Date: 05/12/21 7:42
Date Received: 05/12/21 11:20

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	0.014	mg/L	06/01/21 16:47

- Qualifiers:**
- * Value may exceed the Acceptable Level
 - E Value exceeds the instrument calibration range
 - J Analyte detected below the PQL
 - P Prim./Conf. column %D or RPD exceeds limit
 - B Analyte detected in the associated Method Blank
 - H Holding times for preparation or analysis exceeded
 - ND Not Detected at the Practical Quantitation Limit (PQL)
 - S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.

5854 Butternut Drive

East Syracuse , NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS

Client Sample ID: *HS 040*

Project: Moravia School District

Location:

Lab ID: 2106942-080A

Matrix: PWS

Collection Date: 05/12/21 7:44

Date Received: 05/12/21 11:20

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	0.017 *	mg/L	06/01/21 16:53

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.

5854 Butternut Drive

East Syracuse , NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Moravia School District
Location:
Matrix: PWS

Client Sample ID: *Maint 014*

Lab ID: 2106942-081A
Collection Date: 05/12/21 7:57
Date Received: 05/12/21 11:20

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	0.0028	mg/L	06/01/21 16:55

- Qualifiers:**
- * Value may exceed the Acceptable Level
 - E Value exceeds the instrument calibration range
 - J Analyte detected below the PQL
 - P Prim./Conf. column %D or RPD exceeds limit
 - B Analyte detected in the associated Method Blank
 - H Holding times for preparation or analysis exceeded
 - ND Not Detected at the Practical Quantitation Limit (PQL)
 - S Spike Recovery outside accepted recovery limits

Chain of Custody Record

2106942

Invoiced_Government

200

Telephone # (315) 445-1104

Phone # 315 445-2670

Fax # 997-2260

Contact Person: Dale
315
224-9660

Client: Martha School
Address: 685 Main St
Rochester NY 14618

LSL Project #:
Client's Site I.D.:

LSL Sample Number	Client's Sample Identifications	Authorization:		Sample Time	Sample Type	Matrix	Preserv. Added	Containers		Analyses	Free Cl (mg/L)	Pres. Check
		Sample Date	grab comp.					#	size/type			
001A	H3 08	5-11	X	9:50		PW	None	1	250 ml	Lead		
002A	H3 09	5-4	X	7:50				1				
003	H3 12	5-4	X	7:51				1				
004	H3 13	5-11	X	9:51				1				
005	H3 14	5-4	X	9:51				1				
006	H3 80	5-11	X	9:53				1				
007	H3 81	5-11	X	9:53				1				
008	H3 82	5-11	X	9:53				1				
009	H3 32	5-11	X	9:54				1				
010	H3 20	5-11	X	10:25				1				
011	H3 21		X	10:25				1				
012	H3 22		X	10:26				1				
013	H3 23		X	10:27				1				
014	H3 28	5-11	X	10:28				1				

Notes and Hazard Identifications: 81 Samples

Custody Transfers

Sampled and Relinquished By: M. L. Lape Signature: [Signature] Date: 5/12 Time: 1:09

Relinquished By: _____ Received By: _____

Relinquished By: _____ Received for Lab By: Donald P. [Signature] Date: 5/12/21 Time: 11:20

Shipment Method: _____ Samples Received Intact: Y N 207°C

Chain of Custody Record

2106942

Invoiced_Government

200

Phone # (315) 445-1900
Telefax # (315) 445-1104

Client: Morpine School
Address: 685 Main St
Morpine NY 13118

Contact Person: Dale
LSL Project #: 315 497-2670
Client's Site I.D.: 315 497-2260
004-960

LSL Sample Number	Client's Sample Identifications	Authorization:		Sample Time	Type	Matrix	Preserv. Added	Containers		Analyses	Free Cl (mg/L)	Pres. Check
		Sample Date	Sample Time					#	size/type			
015A	HS 29	5-11	10:29	X	PW	None	1	250 ml	Lead			
016A	HS 30		10:29	X			1					
017A	HS 31		10:29	X			1					
018A	HS 33		10:31	X			1					
019A	HS 34		10:31	X			1					
020A	HS 35		10:31	X			1					
021A	HS 36		10:31	X			1					
022A	HS 01 Pe of ne		10:42	X			1					
023A	HS 02 Bygura		10:42	X			1					
024A	HS 03 Box 61A		10:42	X			1					
025A	HS 04 conf	5-11	10:43	X			1					

Notes and Hazard Identifications:

Custody Transfers

Sampled and Relinquished By: M. [Signature] Signature: [Signature] Date: 5-12 11:04

Relinquished By: _____ Received By: _____

Relinquished By: _____ Received for Lab By: David Amico Date: 5/12/21 11:20

Shipment Method: _____ Samples Received Intact: Y N 20.7°C

Chain of Custody Record

2106942

Invoiced_Government

200

Client: Moravia School
Address: 605 main st
Moravia NY 13118

Contact Person: DALE
LSL Project #: 315 204-9662

Client's Site I.D.:

Client's Project I.D.:

LSL Sample Number	Client's Sample Identifications	Authorization:		Sample Date	Sample Time	Type	grab	comp.	Matrix	Preserv. Added	# Containers	size/type	Analyses	Free Cl (mg/L)	Pres. Check
		Sample Date	Sample Time												
026A	H5 59	5-11	11:06	X					PW	None	1	250 ml	Lead		
027	H5 60		11:06	X							1				
028	H5 61		11:06	X							1				
029	H5 62		11:06	X							1				
030	H5 63		11:06	X							1				
031	H5 64		11:07	X							1				
032	H5 65		11:08	X							1				
033	H5 - 1st fountain		11:08	X							1				
034	H5 - Art room 2		11:08	X							1				
035	H5 Art room 2		11:08	X							1				
036	H5-66		11:23	X							1				
037	H5-67		11:23	X							1				
038	H5-68		11:23	X							1				
039	H5-69	5-11	11:22	X							1				

Notes and Hazard Identifications:

Custody Transfers

Sampled and Relinquished By:	Signature:	Date	Time
Print Name: <u>M. Longman</u>	<u>[Signature]</u>	5-12	11:09
Relinquished By:	Received By:		
Relinquished By:	Received By:		
Relinquished By:	Received for Lab By: <u>Donald Pinella</u>	5/12/21	11:20

Shipment Method:

Samples Received Intact: Y N

20.7°C

Chain of Custody Record

2106942

Invoiced_Government

200

Client: MORAVIA School LSL Project #:
 Address: 675 Main St Phone # 315 497-2670
MORAVIA NY 13118 Fax # 315 497-2260
 Client's Site I.D.: 315 224-9662

LSL Sample Number	Client's Sample Identifications	Authorization:		Sample Date	Sample Time	Type	grab comp.	Matrix	Preserv. Added	Containers #	size/type	Analyses	Free Cl (mg/L)	Pres. Check
		Sample Date	Sample Time											
040A	H5 Wood 1	5/11	11:25	X		PW	None	1	250 ml	Lead				
041	H5 Wood 2		11:25	X				1						
042	H5 76		11:38	X				1						
043	H5 75		11:38	X				1						
044	H5 70		11:39	X				1						
045	H5 71		11:41	X				1						
046	H5 72		11:41	X				1						
047	H5 73		11:41	X				1						
048	H5 74	5/11	11:41	X				1						

Notes and Hazard Identifications:

Custody Transfers

Sampled and Relinquished By: Mark Cooper Signature: [Signature] Date: 5-12 Time: 11:29

Relinquished By: _____ Received By: _____

Relinquished By: _____ Received By: David Pineser Date: 5/12/21 Time: 11:20

Shipment Method: _____ Samples Received Intact: Y N 20.7°C

Chain of Custody Record

2106942

Invoiced_Government

200

Client: Moravia School LSL Project #: _____
 Address: 605 main st Client's Site I.D.: _____
Moravia NY 13118 Contact Person: DATE
 Phone # 497-2670 Matrix PW
 Fax # 497-2260 Preserv. Added None
 Containers: # 1 size/type 250 ml
 Client's Project I.D.: _____
315
204-9660

LSL Sample Number	Client's Sample Identifications	Authorization:		Sample Time	Sample Type	grab comp.	Matrix	Preserv. Added	Containers		Analyses	Free Cl (mg/L)	Pres. Check
		Sample Date	Sample Time						#	size/type			
049A	H5 01	5/12	6:44	X			PW	None	1	250 ml	Lead		
050	H5 02		6:41	X					1				
051	H5 03		6:41	X					1				
052	H5 04		6:41	X					1				
053	H5 07		6:42	X					1				
054	H5 06		6:42	X					1				
055	H5 19		6:43	X					1				
056	H5 05		6:43	X					1				
057	M5-WF		6:45	X					1				
058	H5 15		6:53	X					1				
059	H5 16		6:53	X					1				
060	H5 17		6:53	X					1				
061	H5 18		6:53	X					1				
062	H5 24	5-12	6:58	X					1				

Notes and Hazard Identifications: _____

Custody Transfers

Sampled and Relinquished By: M. Wagoner Signature: _____ Date: 5/12 Time: 11:45

Relinquished By: _____ Received By: _____

Relinquished By: _____ Received By: _____

Relinquished By: _____ Received for Lab By: Donna Kivela Date: 5/12/21 Time: 11:20

Shipment Method: _____ Samples Received Intact: Y N 20.7°C



Life Science Laboratories, Inc.
 5854 Butternut Drive
 East Syracuse, NY 13057

Chain of Custody Record

2106942

Invoiced_Government

200

Client: <u>Moravia School</u>		Telefax # (315) 445-1104		Contact Person: <u>Date</u>		LSL Project #:				
Address: <u>625 main st</u>		Phone # <u>997-2670</u>		<u>315</u>						
<u>Moravia NY 13116</u>		Fax # <u>997-2860</u>		<u>224-9660</u>		Client's Site I.D.:				
LSL Sample Number	Client's Sample Identifications	Authorization:		Matrix	Preserv. Added	Containers		Analyses	Free Cl (mg/L)	Pres. Check
		Sample Date	Sample Time			#	size/type			
063A	H5 27	5/12	7:00	PW	None	1	250 ml	Lead		
064	H5 28		7:02			1				
065	H5 51		7:12			1				
066	H5 52		7:12			1				
067	H5 53		7:12			1				
068	H5 54		7:12			1				
069	H5 55		7:14			1				
070	H5 56		7:16			1				
071	H5 50		7:16			1				
072	H5 49		7:28			1				
073	H5 47		7:30			1				
074	H5 41		7:50			1				
075	H5 46		7:50			1				
076	H5 45	5-12	7:51			1				

Notes and Hazard Identifications:

Custody Transfers

Sampled and Relinquished By:	Signature:	Date	Time
Print Name: <u>M Loophre</u>		<u>5/12</u>	<u>11:09</u>
Relinquished By:	Received By:		
Relinquished By:	Received By:		
Relinquished By:	Received for Lab By: <u>Daniel Risco</u>	<u>5/12/21</u>	<u>11:20</u>
Shipment Method:	Samples Received Intact: <u>Y</u>	<u>N</u>	<u>20.7°C</u>

